



Jeffrey B. Archie
Vice President, Nuclear Operations
803.345.4214

July 24, 2008

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir / Madam:

Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
SPECIAL REPORT (SPR) 2008-004


South Carolina Electric & Gas Company (SCE&G) is submitting this report pursuant to the requirements of Technical Specification 3.3.3.1 b., Table 3.3-6, Action 30. This report addresses the inoperability of the Plant Vent High Range radiation monitor RMA0013 for greater than 72 hours. During the inoperable period, V. C. Summer Nuclear Station (VCSNS) implemented a preplanned alternate method of monitoring in accordance with the requirements of Action 30 of Technical Specification 3.3.3.1 b.

RMA0013 was declared inoperable July 3, 2008, at 0430 hours due to spurious alarms. Further investigation determined that a Universal Digital Ratemeter (UDR) had failed. The UDR was replaced, and the radiation monitor was returned to operable status on July 7, 2008, at 1025 hours.

Due to an administrative error, this report exceeded the 14 day submittal requirements specified in Technical Specification 3.3.3.1.b, Table 3.3-6, Action 30. The failure to submit the report in a timely manner has been entered into the VCSNS corrective action program.

Should you have any questions, please call Mr. Bruce Thompson at (803) 931-5042 at your convenience.

Very truly yours,



Jeffrey B. Archie

JIG/JBA/cm

c: K. B. Marsh
S. A. Byrne
N. S. Carns
J. H. Hamilton
R. J. White
L. A. Reyes
R. E. Martin

NRC Resident Inspector
K. M Sutton
INPO Records Center
NSRC
RTS (CR-08-02936; CR-08-03160)
File (818.08)
PRSF (RC-08-0094)