# TELEPHONE REPORT

FACILITY: Watts Bar Nuclear Plant DOCKET #: 50-390 & 50-391

DATE: January 30, 1979 TIME: 3:00 pm LIC. OCC. #:

SUBJECT: CDR - Metal Shavings in Auxiliary Feedwater Valves Actuators

DESCRIPTION OF OCCURRENCE: TVA notified resident inspector that metal shavings had been found in the hydraulic actuators of four auxiliary feedwater control valves supplied by masoneilan.

Written report due 2/28/79.

RIV notified

McKenzie, Thomas
SIGNATURE

7903200141

S