

REGION II: TELEPHONE REPORT
GEORGIA
GEORGIA

FACILITY: Sequoyia P 3: 42 DOCKET #: 50-327 & 50-328

DATE: February 22, 1979 TIME: 3:20 pm LIC. OCC. #: SWP 79-S-3

SUBJECT: Potential CDR - Essential Raw Cooling Water Drain Valves from Diesel
Generator Heat Exchanger.

DESCRIPTION OF OCCURRENCE: Subject Drain Valves were procured as safety class G rather
than Class C as required for Essential Raw Cooling Water System.

Replacement valves available on site.

Probably applicable to Watts Bar.

If Determined to be reportable a 30 day report is due 3/24/79.

Not reportable under-10 CFR 21

[Handwritten Signature]
SIGNATURE

CC: Thomas
Cochran

CONFIDENTIAL

7903230199

790111
S