39017sc24

TELEPHONE REPORT

FACILITY: Watts Bar 1 & 2 DOCKET #: 50-390 50-391

DATE: 11/22/78 TIME: 4:35pm LIC. OCC. #:

SUBJECT: CDR - Spacing of Catagory I Cable Tray Supports

DESCRIPTION OF OCCURRENCE: Subject not in compliance with design criteria for bracing and supports. Will evaluate by 12/1/78.

From Mark Linn, TVA

RW Wright for McFarland

SIGNATURE

7903260270