

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

September 23, 1982

WBRD-50-390/81-36  
WBRD-50-391/81-35

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - ANCHOR BOLTS INSTALLED NOT IN ACCORDANCE WITH SPACING SPECIFICATIONS - WBRD-50-390/81-36, WBRD-50-391/81-35 - TENTH INTERIM REPORT


The subject deficiency was initially reported to NRC-OIE Inspector R. V. Crlenjak on March 31, 1981 in accordance with 10 CFR 50.55(e) as NCR SWP 8106. Interim reports were submitted on April 30, May 21, June 4, September 16, and December 2, 1981 and January 29, April 13, May 24, and July 28, 1982. We expect to provide additional information on or about December 9, 1982.

TVA is continuing to review the design of engineered support base plates with self-drilling expansion shell (SSD) anchors spacings that are less than required by construction specification G-32 revision 6. These base plates are also being reviewed for reduced spacings to adjacent base plate SSD anchors that were allowed by drawing 47A050-17.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
L. M. Mills, Manager  
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8209300211 820923  
PDR ADOCK 05000390  
S PDR

OFFICIAL COPY

IE 27