

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

September 27, 1982

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - SEISMIC SUPPORTS FOR AUXILIARY
FEEDWATER CONTROL VALVES - NCR EEB 8004 - ADDITIONAL INFORMATION


The subject deficiency was initially reported to NRC-OIE Inspector
M. Thomas on June 24, 1980 in accordance with 10 CFR 50.55(e). Our final
report was submitted on August 22, 1980. This was followed by a supple-
mental information report on June 9, 1982.

In that June 9, 1982 report TVA committed to complete corrective actions on
this deficiency by August 31, 1982. That commitment was met for unit 1.
As discussed with Inspector R. V. Crlenjak on September 7, 1982, TVA has
completed a review of this matter and has determined that the subject
valves were never installed for unit 2, that all required struts for unit 2
valves are now at the site, and any interference problems discovered during
installation will be handled by normal design change requests. The unit 2
valves will be installed during the normal construction schedule. TVA
considers this item resolved and ready for NRC closure.

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555