

rules, regulations, and orders of the Commission, now or hereafter applicable; and is subject to the additional conditions specified and incorporated below:

(1) Maximum Power Level

The licensee is authorized to operate the facility at steady-state reactor core power levels not in excess of 2700 megawatts-thermal in accordance with the conditions specified herein.

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 288, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications.

- (a) For Surveillance Requirements (SRs) that are new, in Amendment 227 to Facility Operating License No. DPR-53, the first performance is due at the end of the first surveillance interval that begins at implementation of Amendment 227. For SRs that existed prior to Amendment 227, including SRs with modified acceptance criteria and SRs whose frequency of performance is being extended, the first performance is due at the end of the first surveillance interval that begins on the date the Surveillance was last performed prior to implementation of Amendment 227.

(3) Additional Conditions

The Additional Conditions contained in Appendix C as revised through Amendment No. 267 are hereby incorporated into this license. Calvert Cliffs Nuclear Power Plant, Inc. shall operate the facility in accordance with the Additional Conditions.

(4) Secondary Water Chemistry Monitoring Program

The Calvert Cliffs Nuclear Power Plant, Inc., shall implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall include:

- a. Identification of a sampling schedule for the critical parameters and control points for these parameters;
- b. Identification of the procedures used to quantify parameters that are critical to control points;