

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

October 15, 1982

WBRD-50-390/82-44

WBRD-50-391/82-41

U.S. Nuclear Regulatory Commission
Region II

Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - USE OF INCORRECT RESPONSE SPECTRA
IN GILBERT/COMMONWEALTH PIPING ANALYSIS - WBRD-50-390/82-44,
WBRD-50-391/82-41 - SECOND INTERIM REPORT


The subject deficiency was initially reported to NRC-OIE Inspector
F. J. Long on April 26, 1982 in accordance with 10 CFR 50.55(e) as NCR
WBN CEB 8207. Our first interim report was submitted on May 27, 1982. We
expect to submit our next report by April 22, 1983. TVA considers 10 CFR
Part 21 applicable to this deficiency.

Problem 0600200-09-05 is continuing to be reanalyzed using the current
east-west direction spectra for elevation 725.0 feet (No. 202). Proper
anchor movements are also being incorporated. This work is being performed
under ECN 3483.

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

8210290052 821015
PDR ADOCK 05000390
S PDR

OFFICIAL COPY

IC 27

82 OCT 18 AID: 11
US NRC REGION II
ATLANTA, GEORGIA