

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
400 Chestnut Street Tower II

September 22, 1983

83 SEP 26 10:53

BLND-50-438/83-33  
BLND-50-439/83-29  
WBRD-50-390/83-29  
WBRD-50-391/83-29

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

BELLEFOUNTE AND MATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INCORRECT MAXIMUM PIPE  
MOVEMENTS - TPIPE PROGRAM - BLND-50-438/83-33, BLND-50-439/83-29  
WBRD-50-390/83-29, WBRD-50-391/83-29 - FINAL REPORT

The subject deficiency was initially reported to NRC-OIE Inspector L. Watson on  
May 4, 1983 in accordance with 10 CFR 50.55(e) as NCR GEN CEB 8303. Our first  
interim report was submitted on May 26, 1983. Enclosed is our final report.  
TVA no longer considers 10 CFR 50.55(e) applicable to NCR GEN CEB 8303.

If you have any questions, please get in touch with R. H. Shell at  
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*L. M. Mills*  
L. M. Mills, Manager  
Nuclear Licensing

Enclosure

cc: Mr. Richard C. DeYoung, Director (Enclosure)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center (Enclosure)  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339

OFFICIAL COPY

Te 27

**ENCLOSURE**

**BELLEFOUNTE AND WATTS BAR NUCLEAR PLANT UNITS 1 AND 2  
INCORRECT MAXIMUM PIPE MOVEMENT**

**NCRs GEN GEN 8303**

**SLRD-50-339/83-33, SLRD-50-339/83-29**

**WNSD-50-390/83-29, WNSD-50-391/83-29**

**10 CFR 50.55(e)**

**FINAL REPORT**

**Description of Deficiency**

Certain piping analysis for Bellefonte and Watts Bar considered the safe shutdown earthquake (SSE) seismic anchor movements by conservatively doubling the results of the operating base earthquake (OBE) seismic anchor movements stress analysis. The results which should be scaled by the appropriate scale factor are stresses, support loads and displacements. A post-processing computer program to combine the results of the stress analysis by the TPIPE computer program applies the scale factor only to the stresses and supports loads and does not scale the displacements. These displacements are included in the total maximum displacement at each support point. Therefore, the unscaled seismic anchor movements could result in unconservative displacement data being placed on support load tables. These errors can occur with all versions of TPIPE and the special post-processor under the following conditions: (1) presence of a seismic anchor load case (load Group 3) in the class 2 post-processor, and (2) a scale factor greater than 1.0 for SCX, SCY, or SCZ.

This deficiency resulted from an error in TPIPE and the special post-processor. The program error resulted from lack of forethought as to how or if SSE anchor point movements should be added to the deadweight, thermal, and SSE response spectrum load cases to yield the maximum pipe movements and supports.

**Safety Implications**

Piping analysis supervisors for all of the potentially affected plants were informed of the error in TPIPE, and information was requested on the impact of previous work. The review of previous cases has been completed, with no analyzes requiring revision as a result of this condition. Therefore, no conditions adverse to the safety of the plant exist, and we no longer consider 10 CFR 50.55(e) applicable.

Upon review of the ASME section III code, no guidelines are given as to how the displacement from SSE anchor point movements should be combined to yield the maximum pipe movements. Furthermore, the ASME Code does not require that SSE anchor point movements pipe stresses be evaluated.

The response spectrum method of analyzing the effect of an earthquake results in conservative displacements. These earthquake-induced displacements are combined with the deadweight and thermal movements to yield a correct maximum pipe movement, seismic anchor movement (SAM), regardless of SSE anchor point case.

The small localized contribution of the SW to the entire piping system, surface movements, and the conservative estimate of the earthquake movement is cause for the TPIE program not to be changed. Since the TPIE special post-processor performs the same function in this area as TPIE, the same conclusion was drawn.