TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

Octob 03 OCT 1983 P 1:51

WBRD-50-390/83-46
WBRD-50-391/83-45

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - ROUTING OF RADIOACTIVE AND NONRADIOACTIVE SYSTEM INSTRUMENT LINES - WBRD-50-390/83-46, WBRD-50-391/83-45 - SECOND INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector Linda Watson on July 29, 1983 in accordance with 10 CFR 50.55(e) as NCR W-130-P. Our first interim report was submitted on August 29, 1983. This constitutes our second interim report. We expect to submit our next report on or about December 21, 1983.

As discussed in our previous report on this deficiency, TVA has elected to remove the instrument drain lines and high point vent lines from the closed drain system with the exception of drain and vent lines on systems 62, 63, 68, 74, 77, 81, and 87 which can contain tritiated wastes. For the excepted lines, the valve positions will be verified by plant instructions. Engineering change notice (ECN) 4287 has been initiated to implement this solution.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8310170264 831006
PDR ADOCK 05000390
S PDR

OFFICIAL COPY
IE27