

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

83 OCT 31 9:32
October 27, 1983

WBRD-50-390/82-72

WBRD-50-391/82-67

U.S. Nuclear Regulatory Commission

Region II

Attn: Mr. James P. O'Reilly, Regional Administrator

101 Marietta Street, NW, Suite 2900

Atlanta, Georgia 30303

Dear Mr. O'Reilly:

**WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - TORNADO DEPRESSURIZATION ON
AUXILIARY BUILDING - WBRD-50-390/82-72, WBRD-50-391/82-67 - SUPPLEMENTAL
INFORMATION**

The subject deficiency was initially reported to NRC-OIE Inspector R. V. Crlenjak on June 23, 1982 in accordance with 10 CFR 50.55(e) as NCR WBN NEB 8213. Interim reports were submitted on July 23 and November 15, 1982; April 12 and August 8, 1983. Our final report was submitted on September 13, 1983.

Please note under corrective actions in our final report (dated September 13, 1983) on the subject NCR that due to a typographical error, door A192 was specified as one of four doors to be opened before tornado depressurization. Door A193 is the door to be opened, not A192.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills

L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8311020274 831027
PDR ADOCK 05000390
S PDR

983-TVA 50TH ANNIVERSARY

An Equal Opportunity Employer

OFFICIAL COPY

IE 27

10