

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

January 19, 1983

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNIT 1 - NRC-OIE REGION II INSPECTION REPORT  
- SUPPLEMENT TO REVISED RESPONSE TO VIOLATION 50-390-82-17-01


The subject report dated June 4, 1982 cited TVA with one Severity Level V Violation in accordance with 10 CFR 2.201. Our initial response to that violation was submitted on July 15, 1982. A revised response to that violation was submitted on October 22, 1982. This notification is a supplement to the revised response.

TVA has underestimated the time required to complete the reinspection of all supports utilizing jam nuts and the application of torque stripping for unit 1 and common facilities. The corrective action (initially specified to be completed by January 10, 1983) will be completed by March 31, 1983.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
L. M. Mills, Manager  
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8303210551 830119  
PDR ADOCK 05000390  
Q PDR

83 JAN 25 P12:45