

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

September 16, 1981

WBRD-50-390/81-36

WBRD-50-391/81-35

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - ANCHOR BOLTS INSTALLED NOT IN
ACCORDANCE WITH SPACING SPECIFICATIONS - WBRD-50-390/81-36, WBRD-50-
391/81-35 - FOURTH INTERIM REPORT


The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on March 31, 1981, in accordance with 10 CFR 50.55(e)
as NCR SWP 8106. TVA considers 10 CFR 21 applicable to this deficiency.
Interim reports were submitted on April 30, May 21, and June 4, 1981.
We expect to provide additional information by December 1, 1981.

TVA has completed the review of the design calculations used to derive the
minimum spacings on drawing 47A050-17. The evaluation to determine which
supports violate the minimum spacing, as specified by General Construction
Specification G-32 For Bolt Anchors Set In Hardened Concrete, is still in
progress.

If you have any questions, please get in touch with D. L. Lambert at
FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

IE27
3
1/0

8109240576 810916
OR ADDCK 05000390
PDR