

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
400 Chestnut Street Tower II

October 7, 1981

WBRD-50-390/81-54  
WBRD-50-391/81-52

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - FOXBORO MCA TRANSMITTERS -  
WBRD-50-390/81-54, WBRD-50-391/81-52 - THIRD INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector R. V. Crlenjak on June 29, 1981 in accordance with 10 CFR 50.55(e) as NCR WBN EEB 8109, Interim reports were submitted on July 27 and September 3, 1981. We expect to submit our next report by December 11, 1981. TVA considers 10 CFR 21 applicable to this deficiency.

TVA is still in the process of inspecting all applicable Foxboro MCA transmitters and will replace defective amplifiers in the transmitters as required.

If you have any questions concerning this matter, please get in touch with M. R. Wisenburg at FTS 857-2778.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*L. M. Mills*  
L. M. Mills, Manager  
Nuclear Regulation and Safety

cc: Mr. Victor Stallo, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

IE27  
s  
1/0