

TENNESSEE VALLEY AUTHORITY  
U.S. NRC REGION II  
CHATTANOOGA, TENNESSEE 37402  
ATLANTA, GEORGIA  
400 Chestnut Street Tower II

October 26, 1981 OCT 28 AS: 14

WBRD-50-390/81-85  
WBRD-50-391/81-78

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - DRAWING CONTROL -  
WBRD-50-390/81-85, WBRD-50-391/81-78 - FIRST INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector R. V. Calenjak on September 24, 1981 in accordance with 10 CFR 50.55(e) as NCR's WB-C-81-05 and W-58-P. Enclosed is our first interim report. We expect to submit our next report by January 21, 1982.

If you have any questions, please get in touch with R. H. Shell at PTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager  
Nuclear Regulation and Safety

Enclosure

cc: Mr. Victor Stello, Director (Enclosure)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

IED?  
3  
1/1

8111030490 811026  
PDR ADOCK 05000390  
S PDR

ENCLOSURE

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2  
DRAWING CONTROL  
WBRD-50-390/81-85, WBRD-50-391/81-78  
10 CFR 50.55(e)  
FIRST INTERIM REPORT

Description of Condition

During a TVA audit, it was found that certain drawings which were available for use during construction were not properly controlled in that some of these drawings had been superseded by later revisions. Out of 60 drawings which were audited, 7 were not the current revision. This is similar to items previously identified in TVA audits as well as NRC violation 50-390/31-09-04. In addition, it has been identified that the latest revision of some as-constructed drawings did not accurately depict the current plant configuration.

Interim Progress

TVA is investigating this deficiency and will provide further information in our next report.