TENNESSEE VALLEY AUTHORITY

CHATTANOOGA TENNESSEE 37401 400 Chestnut Street Tower II

34 MAR 14 ANd ich 7, 1984

WBRD-50-390/83-06

U.S. Nuclear Regulatory Commission Region II Attn: Mr. James P. O'Reilly, Regional Administrator 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNIT 1 - SUPPORTS NOT DESIGNED OR MODIFIED AS REQUIRED BY ECN 2576 - WBRD-50-390/83-06 - <u>SUPPLEMENTAL INFORMATION</u>

The subject deficiency was initially reported to NRC-OIE Inspector P. Fredrickson on January 18, 1983 in accordance with 10 CFR 50.55(e) as NCR WBN SWP 8301 R1. Interim reports were submitted on February 16, June 6, and August 19, 1983. Our final report was submitted on October 17, 1983. This constitutes a supplement to the final report.

In our final report on this item, only one Engineering Change Notice (ECN) was referenced in the corrective action. This ECN, No. 4080, was issued to implement required design changes identified in the TVA review of the support designs for all rigorously-analyzed piping. The original 21 support design deficiencies identified by Black and Veatch (B&V) are being corrected under ECN 3198 (an ongoing major reanalysis ECN at the time of the B&V review which already included several of the supports field of the supports identified by B&V). The design and subsequent construction will be completed by May 17, 1984.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

7m mills

L. M. Mills, Manager Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director Office of Inspection and Enforcement U.S. Nuclear Regulatory Commission Washington, D.C. 20555

> Records Center Institute of Nuclear Power Operations 1100 Circle 75 Parkway, Suite 1500 Atlanta, Georgia 30339

8403190099 840308 PDR ADOCK 05000390 S PDR

OFFICIAL COPY TICID

1983-TVA 50TH ANNIVERSARY

An Equal Opportunity Employer