TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401
1630 Chestnut Street Tower II

85 FEB 1 P1:04

January 30, 1985

WBRD-50-390/83-66
WBRD-50-391/83-61

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Attention: Mr. James P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - FAILURE TO PROVIDE SELF-CONTAINED LIGHTS AS COMMITTED TO NRC WBRD-50-390/83-66 AND WBRD-50-391/83-61 - SUPPLEMENTAL REPORT

The subject deficiency was initially reported to NRC-OIE Inspector Linda Watson on November 9, 1983 in accordance with 10 CFR 50.55(e) as NCR WBN MEB 8305. This was followed by our final report dated December 13, 1983. Our supplemental report for unit 2 is as follows.

As discussed with Inspector Al Ignatonis on January 15, 1985, the date of December 30, 1984 for completion of corrective actions indicated in our final report on this matter was not met. While the unit 1 commitments have been completed per ECN 4412, the installation of unit 2 lights through ECN 4413 has been rescheduled. The corrective action on this matter will be completed by April 10, 1986.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

David S. Lambert for

J. W. Hufham, Manager
Licensing and Regulations

cc: See Page 2

8502210358 850130
PDR ADOCK 05000390
S PDR

OFFICIAL COPY
IE 27
1/0

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339