

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37424  
400 Chestnut Street Tower 11

NRC REGION II  
ATLANTA, GEORGIA

March 16, 1982 MAR 18 A 9: 27

WBRD-50-391/81-98  
WBRD-50-391/81-92

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - DEFICIENT CONTAINMENT ISOLATION VALVE SIGNAL AND FUNCTION - WBRD-50-390/81-98, WBRD-50-391/81-92 - SECOND INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector T. Quick on November 9, 1981 in accordance with 10 CFR 50.55(e) as NCR WBN NEB 8121. Our first interim report was submitted on December 10, 1981. We expect to submit out next report on or about May 17, 1982.

TVA is initiating the drawing revisions necessary to provide a containment isolation signal to valve FCV-62-76. The drawing revisions are presently scheduled to be completed by April 15, 1982.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager  
Nuclear Regulation and Safety

cc: Mr. Richard C. DeYoung, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

OFFICIAL COPY

12 27  
3/10

8204020436 820316  
PDR ABOCK 05000390  
S PDR