TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

83 JAN 27 A10:12

January 20, 1983

WBRD-50-390/81-26
WBRD-50-391/81-25

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - RETRIEVABLE INFORMATION USED IN PIPING ANALYSIS - WBRD-50-390/81-26 AND WBRD-50-391/81-25 - SEVENTH INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector R. V. Crlenjak on March 16, 1981 in accordance with 10 CFR 50.55(e) as NCR WBN CEB 8104. Interim reports were submitted on April 10, June 11, and September 14, 1981 and February 1, March 16, and August 5, 1982. We expect to provide additional information on or about May 12, 1983.

As continued corrective action, TVA has reviewed and updated data included in the Watts Bar Master Valves Status Reports (MVSR) (which combines reports RPT009 and RPT010) that was judged to be information requiring quality control. A draft of an engineering procedure which will define and control the use and maintenance of the MVSR has been written and is now being reviewed.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills

L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

8302010230 830120
PDR ADOCK 05000390
S PDR

OFFICIAL COPY

IE 27