

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

February 8, 1983

WBRD-50-390/82-58
WBRD-50-391/82-55

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - CONCRETE ANCHORAGE FREE EDGE
VIOLATION - WBRD-50-390/82-58, WBRD-50-391/82-55 - THIRD INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector D. Quick on May 28, 1982 in accordance with 10 CFR 50.55(e) as NCR 4068R. Interim reports were submitted on June 24, and October 26, 1982. Enclosed is our third interim report. We expect to submit our next report on or about June 24, 1983.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

A. M. Mills
A. M. Mills, Manager
Nuclear Licensing

Enclosure

cc: Mr. Richard C. DeYoung, Director (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

OFFICIAL COPY

IE 27

8302170356 830208
PDR ADOCK 05000390
S PDR

ENCLOSURE

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2
CONCRETE ANCHORAGE FREE EDGE VIOLATION
NCR 4068R
WBRD-50-390/82-58, WBRD-50-391/82-55
10 CFR 50.55(e)
THIRD INTERIM REPORT

Interim Progress

A field survey was conducted which identified all of the potentially deficient grouted anchors and anchor bolt spacing violations (free edge distance) associated with this nonconformance. Evaluations are currently being performed to determine the adequacy of the anchorages. Additional information will be submitted in our next report.