

**From:** Brenda Mozafari  
**Sent:** Thursday, August 07, 2008 3:49 PM  
**To:** 'Ken\_Frehafer@fpl.com'  
**Cc:** Tom Boyce (NRR); Harold Walker; Robert Dennig  
**Subject:** RAI for TSTF 448 St. Lucie Units 1 and 2 (MD6174 and MD6175)

Ken,

Here is the question we are sending tomorrow formally. Your response is expected before August 28.

REQUEST FOR ADDITIONAL INFORMATION  
ST. LUCIE UNITS 1 AND 2  
CONTROL ROOM HABITABILITY, TSTF-448  
DOCKET NOS. 50-335 AND 50-389

By letter dated May 20, 2008 (Agency Document and Management System (ADAMS) No. ML081440425), Florida Power and Light Company (the licensee) submitted an update to a license amendment request to change the Technical Specifications for St. Lucie units 1 and 2 in accordance with TSTF-448. On pages 2 of 16 and 9 of 16 of attachment 2 of the letter at 3/4.7.7, identification of the Control Room Emergency Ventilation System (CREVS) and the Control Room Emergency Air Cleanup System (CREACS) for Units 1 and 2 are provided respectively. However, USFAR sections 9.4.1 for Units 1 and 2 identify these systems somewhat differently. The Control Room Emergency Ventilation System in the Technical Specifications for Unit 1 is identified in the USFAR as the Control Room Ventilation System. The Control Room Emergency Air Cleanup System in the Technical Specification for Unit 2 seems to be identified in the USFAR as a combination of two systems, (1) the Control Room Air Conditioning System and (2) the Control Room Emergency Cleanup System. Because of the inconsistencies it is not clear that the systems identified in the Technical Specifications are the same systems identified in the USFAR. We are requesting that you clarify the discrepancies.

*BRENDA MOZAFARI  
SENIOR PROJECT MANAGER  
NUCLEAR REGULATORY COMMISSION*

*SAINT LUCIE 1 AND 2; TURKEY POINT 3 AND 4*

*301-415-2020*

---

## E-mail Properties

### Mail Envelope Properties ()

Subject: RAI for TSTF 448 St. Lucie Units 1 and 2 (MD6174 and MD6175)  
Sent Date: 8/7/2008 3:43:03 PM  
Received Date: 8/7/2008 3:49:00 PM  
From: Brenda Mozafari

Created By: Brenda.Mozafari@nrc.gov

### Recipients:

Ken\_Frehafer@fpl.com ('Ken\_Frehafer@fpl.com')  
Tracking Status: None  
Tom.Boyce@nrc.gov (Tom Boyce (NRR))  
Tracking Status: None  
Harold.Walker@nrc.gov (Harold Walker)  
Tracking Status: None  
Robert.Dennig@nrc.gov (Robert Dennig)  
Tracking Status: None

### Post Office:

Files	Size	Date & Time
MESSAGE	10953	8/7/2008

### Options

Expiration Date:  
Priority: olImportanceNormal  
ReplyRequested: False  
Return Notification: False

Sensitivity: olNormal  
Recipients received: ZZZ