

August 19, 2008

Vice President, Operations  
Entergy Nuclear Operations, Inc  
Indian Point Energy Center  
450 Broadway, GSB  
P.O. Box 249  
Buchanan, NY 10511-0249

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 - INDIVIDUAL NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR HEARING RE: ALLOWABLE COMPLETION TIME FOR OFFSITE AC SOURCES (TAC NO. MD9348)

Dear Sir or Madam:

The Nuclear Regulatory Commission has forwarded the enclosed "Notice of Consideration of Issuance of Amendment to Renewed Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," to the Office of the Federal Register for publication.

This notice relates to your application dated July 30, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082180351), to revise the Indian Point Nuclear Generating Unit No. 2 Technical Specification (TS) 3.8.1, Required Action A.4, to allow a one time extension to the completion time for the loss of one offsite power circuit from 72 hours to 144 hours. This change will ensure that there is enough time for the failed oil cooling pump on the station auxiliary transformer to be removed, the new oil cooling pump to be installed, and the new oil cooling pump to be tested in place.

If you have any questions, please contact me at 301-415-2901.

Sincerely,

*/RA/*

John P. Boska, Senior Project Manager  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosure:  
As stated

cc w/encl: See next page

Indian Point Nuclear Generating Unit No. 2

cc:

Senior Vice President  
Entergy Nuclear Operations, Inc.  
P.O. Box 31995  
Jackson, MS 39286-1995

Vice President Oversight  
Entergy Nuclear Operations, Inc.  
P.O. Box 31995  
Jackson, MS 39286-1995

Senior Manager, Nuclear Safety &  
Licensing  
Entergy Nuclear Operations, Inc.  
P.O. Box 31995  
Jackson, MS 39286-1995

Senior Vice President and COO  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Manager, Licensing  
Entergy Nuclear Operations, Inc.  
Indian Point Energy Center  
450 Broadway, GSB  
P.O. Box 249  
Buchanan, NY 10511-0249

Mr. Paul Tonko  
President and CEO  
New York State Energy, Research, and  
Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. John P. Spath  
New York State Energy, Research, and  
Development Authority  
17 Columbia Circle  
Albany, NY 12203-6399

Mr. Paul Eddy  
New York State Department  
of Public Service  
3 Empire State Plaza  
Albany, NY 12223-1350

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Senior Resident Inspector's Office  
Indian Point 2 and 3  
U. S. Nuclear Regulatory Commission  
P.O. Box 59  
Buchanan, NY 10511

Mr. Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Mr. Raymond L. Albanese  
Four County Coordinator  
200 Bradhurst Avenue  
Unit 4 Westchester County  
Hawthorne, NY 10532

Mayor, Village of Buchanan  
236 Tate Avenue  
Buchanan, NY 10511

Mr. Jim Riccio  
Greenpeace  
702 H Street, NW  
Suite 300  
Washington, DC 20001

Mr. Phillip Musegaas  
Riverkeeper, Inc.  
828 South Broadway  
Tarrytown, NY 10591

Indian Point Nuclear Generating Unit No. 2

cc:

Mr. Mark Jacobs  
IPSEC  
46 Highland Drive  
Garrison, NY 10524

Mr. Sherwood Martinelli  
FUSE USA  
via email

August 19, 2008

Vice President, Operations  
Entergy Nuclear Operations, Inc  
Indian Point Energy Center  
450 Broadway, GSB  
P.O. Box 249  
Buchanan, NY 10511-0249

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 - INDIVIDUAL NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR HEARING RE: ALLOWABLE COMPLETION TIME FOR OFFSITE AC SOURCES (TAC NO. MD9348)

Dear Sir or Madam:

The Nuclear Regulatory Commission has forwarded the enclosed "Notice of Consideration of Issuance of Amendment to Renewed Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," to the Office of the Federal Register for publication.

This notice relates to your application dated July 30, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082180351), to revise the Indian Point Nuclear Generating Unit No. 2 Technical Specification (TS) 3.8.1, Required Action A.4, to allow a one time extension to the completion time for the loss of one offsite power circuit from 72 hours to 144 hours. This change will ensure that there is enough time for the failed oil cooling pump on the station auxiliary transformer to be removed, the new oil cooling pump to be installed, and the new oil cooling pump to be tested in place.

If you have any questions, please contact me at 301-415-2901.

Sincerely,

*/RA/*

John P. Boska, Senior Project Manager  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosure:  
As stated

cc w/encl: See next page

DISTRIBUTION:

PUBLIC LPL1-1 R/F RidsNrrPMJBoska RidsNrrDorLp1-1  
RidsOGCMailCenter RidsNrrLASLittle (hard copy) RidsNrrDorIDpr  
Accession Number: ML082210182 Package ML082210256 Letter ML082210182 FRN  
ML082210241

OFFICE	LPL1-1\PM	LPL1-1\LA	LPL1-1\BC	
NAME	JBoska	SLittle	MKowal	
DATE	8/14/08	8/18/08	8/19/08	

Official Record Copy