

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

November 15, 1982

WBRD-50-390/82-42  
WBRD-50-391/82-39  
BLRD-50-438/82-34  
BLRD-50-439/82-31

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR AND BELLEVONTE NUCLEAR PLANTS UNITS 1 AND 2 - QUALIFICATION OF  
RHR/DHR SUMP VALVE ROOM - WBRD-50-390/82-42, WBRD-50-391/82-39,  
BLRD-50-438/82-34, BLRD-50-439/82-31 - THIRD INTERIM REPORT

NOV 19 11:00  
RECEIVED

The subject deficiency was initially reported to NRC-OIE Inspector  
R. V. Crlenjak on April 22, 1982 in accordance with 10 CFR 50.55(e)  
as NCRs WBN NEB 8207 for Watts Bar and BLN NEB 8204 for Bellefonte.  
Interim reports were submitted on June 7 and September 8, 1982. We expect  
to submit our next report on about February 24, 1983.

As stated in our first report, TVA does not consider the subject  
nonconformance documents a problem which would adversely affect the safe  
operation of the plant. TVA is, however, considering design enhancements  
for the RHR/DHR sump valve rooms in the form of a leak monitoring system  
similar to that described in Standard Review Plan section 6.2.b. The cause  
and actions to prevent recurrence for the subject nonconformance will be  
provided in our next report.

If you have any questions, please get in touch with R. H. Shell at  
PTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*L. M. Mills*  
L. M. Mills, Manager  
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

NOV 27 1982