

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

November 29, 1982

WBRD-50-390/81-73
WBRD-50-391/81-69

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:


WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - DIESEL GENERATOR ROOM EXHAUST FAN
MODIFICATION - WBRD-50-390/81-73, WBRD-50-391/81-69 - SIXTH INTERIM
REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on August 31, 1981 in accordance with 10 CFR 50.55(e)
as NCR W-51-P. Interim reports were submitted on September 30 and
December 2, 1981 and February 17, March 16, and July 12, 1982. TVA is
still working on the design modification to provide structural stiffeners
to reduce lateral vibration of the subject fans. Our next report will be
submitted on or about February 25, 1983.

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

OFFICIAL COPY
I E 27

8212070142 821129
PDR ADOCK 05000390
8 PDR