

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

January 11, 1983

WBRD-50-390/82-31  
WBRD-50-391/82-28

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - NO EVIDENCE THAT AUXILIARY  
FEEDWATER PUMP COMPONENTS MEET CODE REQUIREMENTS, ASME CLASS 3, TVA CLASS C  
- WBRD-50-390/82-31, WBRD-50-391/82-28 - THIRD INTERIM REPORT


The subject deficiency was initially reported to NRC-OJE Inspector  
R. V. Crlenjak on March 30, 1982 in accordance with 10 CFR 50.55(e) as NCR  
3755R. Interim reports were submitted on May 11 and July 2, 1982. We  
expect to submit our next report on or about July 1, 1983.

Drawings have been revised to indicate the vendor's scope of supply and to  
define the TVA safety class at all such interfaces. Remaining design work  
associated with this nonconformance is being completed under ECM 3198.  
Also, TVA is still reviewing the questioned components to verify that they  
were installed in accordance with TVA Class C requirements.

If you have any questions, please get in touch with R. H. Shell at  
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager  
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8301170280 830111  
PDR ADOCK 05000390  
S PDR

OFFICIAL COPY  
IE 27