TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

January 11, 1983

WBRD-50-390/82-31
WBRD-50-391/82-28

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - NO EVIDENCE THAT AUXILIARY FEEDWATER PUMP COMPONENTS MEET CODE REQUIREMENTS, ASME CLASS 3, TVA CLASS C - WBRD-50-390/82-31, WBRD-50-391/82-28 - THIRD INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector R. V. Crlenjak on March 30, 1982 in accordance with 10 CFR 50.55(e) as NCR 3755R. Interim reports were submitted on May 11 and July 2, 1982. We expect to submit our next report on or about July 1, 1983.

Drawings have been revised to indicate the vendor's scope of supply and to define the TVA safety class at all such interfaces. Remaining design work associated with this nonconformance is being completed under ECN 3198. Also, TVA is still reviewing the questioned components to verify that they were installed in accordance with TVA Class C requirements.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

8301170280 830111
PDR ADOCK 05000390
S PDR

OFFICIAL COPY
IE 27

An Equal Opportunity Employer