

August 15, 2008

Mr. Robert E. Brown
Senior Vice President, Regulatory Affairs
GE Hitachi Nuclear Energy
3901 Castle Hayne Road MC A-50
Wilmington, NC 28401

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 241 RELATED TO
ESBWR DESIGN CERTIFICATION APPLICATION

Dear Mr. Brown:

By letter dated August 24, 2005, GE Hitachi Nuclear Energy submitted an application for final design approval and standard design certification of the economic simplified boiling water reactor (ESBWR) standard plant design pursuant to 10 CFR Part 52. The U.S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed design.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

If you have any questions or comments concerning this matter, you may contact me at 301-415-2375 or leslie.perkins@nrc.gov, or you may contact Eric Oesterle at 301-415-1365 or eric.oesterle@nrc.gov.

Sincerely,

/RA/

Leslie Perkins, Project Manager
ESBWR/ABWR Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket No. 52-010

Enclosure:
Request for Additional Information

cc: See next page

August 15, 2008

Mr. Robert E. Brown
Senior Vice President, Regulatory Affairs
GE Hitachi Nuclear Energy
3901 Castle Hayne Road MC A-50
Wilmington, NC 28401

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 241 RELATED TO
ESBWR DESIGN CERTIFICATION APPLICATION

Dear Mr. Brown:

By letter dated August 24, 2005, GE Hitachi Nuclear Energy submitted an application for final design approval and standard design certification of the economic simplified boiling water reactor (ESBWR) standard plant design pursuant to 10 CFR Part 52. The U.S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed design.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

If you have any questions or comments concerning this matter, you may contact me at 301-415-2375 or leslie.perkins@nrc.gov, or you may contact Eric Oesterle at 301-415-1365 or eric.oesterle@nrc.gov.

Sincerely,

/RA/

Leslie Perkins, Project Manager
ESBWR/ABWR Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket No. 52-010

Enclosure:
Request for Additional Information
cc: See next page
Distribution: See next page

ADAMS ACCESSION NO. ML082260383

NRO-002

OFFICE	PM:NGE2:NRO	PM:NGE1:NRO	PM:NGE1:NRO
NAME	LPerkins	EOesterle	ACubbage-EOesterle for:
DATE	08/13/08	08/13/08	08/15/08

OFFICIAL RECORD COPY

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO.241 RELATED TO
ESBWR DESIGN CERTIFICATION APPLICATION DATED AUGUST 15, 2008

Distribution:
PUBLIC

Hard Copy
NGE1/2 R/F
LPerkins, NRO
EOesterle, NRO
ACubbage, NRO

E-Mail:
RidsNroDnrlNge1
RidsNroDnrlNge2
RidsAcrsAcnwMailCenter
RidsOgcMailCenter
KWinsberg, OGC
JJolicoeur, RES
SMarshall, RES

**Requests for Additional Information (RAIs)
ESBWR Design Control Document (DCD), Revision 5**

RAI Number	Reviewer	Question Summary	Full Text
14.3-217 S02	Haider S Forrest E	EFU Testing and CRHA pressure control	<p>A. Revise the design commitment (DC) for item 10 in Tier 1, table 2.16.2-6 of to show that the filter testing requirements are based on Regulatory Guided 1.52. And revise the acceptance criteria (AC) to show that filter efficiency testing is not the in place leakage test (covered in item 7) but is a laboratory test as per Regulatory Guide 1.52.</p> <p>B. Revise the DC in item 12 in Tier 1, table 2.16.2-6 to show that the EFU can maintain the habitable conditions indefinitely or at least for the duration of any accident. The 72 hour value is not applicable here.</p>
14.3-405	Oesterle E	ITAAC roadmap	<p>SRP 14.3, Section III, Review Procedures, as well as Appendix C, Detailed Review Guidance, discuss the need for the staff to review cross-references in DCD Tier 2, Section 14.3, showing where key parameters from safety analyses for the design, including, analyses of design-basis accidents, severs accidents, flooding, overpressure protection, containment, core cooling, fire protection, transients, shutdown risk, anticipated transient without scram, Three Mile Island (TMI) items, PRAs, regulatory treatment of nonsafety-related systems (RT Enclosure analyses as specified by the staff. The applicant did not provide these roadmaps in Tier 2 of the ESBWR DCD, Rev. 5. The applicant is requested to provide these cross-references/roadmaps in Tier 2, Section 14.3 of the ESBWR DCD. Guidance on the format and content for these cross-references may be gleaned by referring to Tables 14.3-1 through 14.3-8 in the AP1000 Design Control Document.</p>
14.3-406	Pal A	ITAAC for containment electrical penetration	<p>DCD, Tier 1, Section 2.15 regarding ITAAC items in electrical areas is inadequate. Include ITAAC for the following items or provide justification for not including them:</p>

RAI Number	Reviewer	Question Summary	Full Text
			<p>a) Verification that all electrical containment penetrations are protected against postulated currents greater than their continuous current rating.</p> <p>b.) Verification that electrical containment penetration circuits are protected by redundant protective devices in accordance to RG 1.63.</p>
14.3-407	Pal A	Containment electrical penetrations are missing from in Tier 1 Tables 2.15.1-1	Containment electrical penetrations are missing from Tables 2.15.1-1a, 1b, and 1c. in Tier 1. Add all containment penetrations in appropriate Table.
14.3-408	Pal A	Table 2.13.1-1 is incomplete	<p>In DCD, Tier 1, Section 2.13.1-1, Table 2.13.1-1 is incomplete. Include the following or provide justification for not including them:</p> <p>a) Breaker to regulating transformer and relay (degraded voltage and under-frequency) compartments.</p> <p>b) Ancillary diesel buses</p>
14.3-409	Pal A	Figure 2.13.1-1 is incomplete	<p>In DCD, Tier 1, Figure 2.13.1-1 Sh. 2 is not complete. Correct figure as stated below:</p> <p>a) The figure is missing ancillary diesel bus,</p> <p>b) 480 V buses do not include all loads [e.g., UPS rectifiers, regulating transformers, etc.],</p> <p>c) PIP bus A feeds to Isolation Power Center Bus A alternate feed is incorrect,</p> <p>d) PIP bus B feeds Isolation Power Center Bus D alternate feed is incorrect</p>

RAI Number	Reviewer	Question Summary	Full Text
14.3-410	Pal A	ITAAC items missing from Table 2.13.4-2	<p>In DCD, Tier 1, Section 2.13.4, Table 2.13.4-2 is incomplete. Include ITAAC for the following items or provide justification for not including them:</p> <ul style="list-style-type: none"> a) Verification of automatic load sequencing b) Verification that Control exist in the MCR to start and stop each SDG c) Verification that Ancillary diesel generator and associated auxiliaries, control, electrical buses, fuel tanks, etc. are Seismic Category II.
14.3-411	Pal A	Section 2.13.5 is incomplete	<p>In DCD, Tier 1, Section 2.13.5 is incomplete. Include the following items or provide justification for not including them:</p> <ul style="list-style-type: none"> a) Control Building and Reactor Building distribution panels are missing from Table 2.13.5-1. b) In Table 2.13.5-2, item 6 should include maximum and minimum battery terminal voltages in design commitment. Acceptance criteria for item 6 should specify voltage and frequency tolerances. c) An item should be added for regulating transformers. In case of one inverter problem, regulating transformer and other inverter will supply power. Provide synchronization scheme to be used. Add as another ITAAC item.
14.3-412	Pal A	Inconsistencies in figures	<p>Explain why the figures in DCD Tier 1, Section 2.13 are not consistent with DCD Tier 2, Chapter 8 figures.</p>
14.3-413	Pal A	Trip coordination of battery chargers and UPS input rectifiers with inverters.	<p>In response to RAI 8.2-14 related to the effects of voltage spike on the electrical distribution system components after loss of the electrical grid during islanding, GEH stated that fast transients on the AC input to the UPS input rectifiers and battery chargers can result in high DC voltages and, if the rectifiers and inverter trips are not coordinated subsequent inverter trips and loss of power to safety-related loads can occur. Since</p>

RAI Number	Reviewer	Question Summary	Full Text
			trip coordination of battery chargers and UPS input rectifiers with inverters is critical for proper operation of UPS under excessive ac input voltage conditions during islanding mode, an ITAAC is necessary to verify the trip coordination of safety-related battery chargers and UPS input rectifiers with inverters. Provide an ITAAC to address proper operation of the above devices under all conditions including transients.

DC GE - ESBWR Mailing List

(Revised 08/11/2008)

cc:

Ms. Michele Boyd
Legislative Director
Energy Program
Public Citizens Critical Mass Energy
and Environmental Program
215 Pennsylvania Avenue, SE
Washington, DC 20003

Mr. Ray Ganthner
Senior Vice President
AREVA, NP, Inc. 3315
Old Forest Road
P.O. Box 10935
Lynchburg, VA 24506-0935

DC GE - ESBWR Mailing List

Email

aec@nrc.gov (Amy Cubbage)
APH@NEI.org (Adrian Heymer)
art.alford@ge.com (Art Alford)
awc@nei.org (Anne W. Cottingham)
bennettS2@bv.com (Steve A. Bennett)
bevans@enercon.com (Bob Evans)
bob.brown@ge.com (Robert E. Brown)
BrinkmCB@westinghouse.com (Charles Brinkman)
cberger@energetics.com (Carl Berger)
charles.bagnal@ge.com
chris.maslak@ge.com (Chris Maslak)
CumminWE@Westinghouse.com (Edward W. Cummins)
cwaltman@roe.com (C. Waltman)
dan1.williamson@ge.com (Dan Williamson)
david.hinds@ge.com (David Hinds)
david.lewis@pillsburylaw.com (David Lewis)
David.piepmeyer@ge.com (David Piepmeyer)
dlochbaum@UCSUSA.org (David Lochbaum)
don.lewis@ge.com (Don Lewis)
erg-xl@cox.net (Eddie R. Grant)
Eugene_Grecheck@dom.com (Eugene S. Grecheck)
frankq@hursttech.com (Frank Quinn)
Frostie.white@ge.com (Frostie White)
gcesare@enercon.com (Guy Cesare)
GEH-NRC@hse.gsi.gov.uk (Geoff Grint)
george.honma@ge.com (George Honma)
george.wadkins@ge.com (George Wadkins)
GovePA@BV.com (Patrick Gove)
greshaja@westinghouse.com (James Gresham)
gzinke@entergy.com (George Alan Zinke)
hickste@earthlink.net (Thomas Hicks)
james.beard@gene.ge.com (James Beard)
jeff.waal@ge.com (Jeff Waal)
jgutierrez@morganlewis.com (Jay M. Gutierrez)
Jim.Kinsey@inl.gov (James Kinsey)
jim.riccio@wdc.greenpeace.org (James Riccio)
jim.rogers@ge.com (Jim Rogers)
JJNesrsta@cpsenergy.com (James J. Nesrsta)
joel.Friday@ge.com (Joel Friday)
John.O'Neill@pillsburylaw.com (John O'Neill)
john.sorensen@ge.com (John Sorensen)
Joseph_Hegner@dom.com (Joseph Hegner)
junichi_uchiyama@mnes-us.com (Junichi Uchiyama)
kathy.warnock@ge.com (Kathy Warnock)

DC GE - ESBWR Mailing List

kenneth.ainger@exeloncorp.com (Kenneth Ainger)
kimberly.milchuck@ge.com (Kimberly Milchuck)
KSutton@morganlewis.com (Kathryn M. Sutton)
kurt.schaefer@ge.com (Kurt Schaefer)
kwaugh@impact-net.org (Kenneth O. Waugh)
laura.bello@ge.com (Laura Bello)
lee.dougherty@ge.com
lou.lanese@ge.com (Lou Lanese)
Marc.Brooks@dhs.gov (Marc Brooks)
maria.webb@pillsburylaw.com (Maria Webb)
mark.beaumont@wsms.com (Mark Beaumont)
Marvin.Smith@dom.com (Marvin L. Smith)
matias.travieso-diaz@pillsburylaw.com (Matias Travieso-Diaz)
media@nei.org (Scott Peterson)
mike_moran@fpl.com (Mike Moran)
MSF@nei.org (Marvin Fertel)
mwetterhahn@winston.com (M. Wetterhahn)
nirsnet@nirs.org (Michael Mariotte)
PAC2@nrc.gov (Peter Cochran)
pareez.golub@ge.com (Pareez Golub)
Pat.Woodfin@ge.com (Pat Woodfin)
patriciaL.campbell@ge.com (Patricia L. Campbell)
paul.gaukler@pillsburylaw.com (Paul Gaukler)
Paul@beyondnuclear.org (Paul Gunter)
peter.jordan@ge.com (Peter Jordan)
phinnen@entergy.com (Paul Hinnenkamp)
pshastings@duke-energy.com (Peter Hastings)
randy.newton@ge.com (Randy Newton)
rick.kingston@ge.com (Rick Kingston)
RJB@NEI.org (Russell Bell)
RKTemple@cpsenergy.com (R.K. Temple)
Robert.Peters@ge.com (Robert Peters)
roberta.swain@ge.com (Roberta Swain)
Russell.Wells@Areva.com (Russell Wells)
sandra.sloan@areva.com (Sandra Sloan)
SauerB@BV.com (Robert C. Sauer)
sfrantz@morganlewis.com (Stephen P. Frantz)
steven.hucik@ge.com (Steven Hucik)
tdurkin@energetics.com (Tim Durkin)
tom.childress@ge.com
tom.miller@hq.doe.gov (Tom Miller)
trsmith@winston.com (Tyson Smith)
Vanessa.quinn@dhs.gov (Vanessa Quinn)
VictorB@bv.com (Bill Victor)
Wanda.K.Marshall@dom.com (Wanda K. Marshall)

DC GE - ESBWR Mailing List

wayne.cutright@ge.com (Wayne Cutright)
wayne.marquino@ge.com (Wayne Marquino)
whorin@winston.com (W. Horin)