

ENCLOSURE 1

NOTICE OF VIOLATION

Tennessee Valley Authority
Watts Bar

Docket Nos. 50-390 and 50-391
License Nos. CPPR-91 and CPPR-92

The following violation was identified during an inspection conducted on January 31 - February 3, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50, Appendix B, Section V states, in part, that activities affecting quality shall be prescribed by documented instructions, procedures, or drawings, of a type appropriate to the circumstances and shall be accomplished in accordance with these instructions, procedures, or drawings.

Revision 4 of the Watts Bar Training Instruction Letter, section 11, requires that the responsible shift engineer will be responsible for certifying that each cold license candidate in his crew has satisfactorily completed the systems walk-through requirements and that the shift engineer will complete walk-through examinations and forward them to the Operations Supervisor.

Contrary to the above, plant system familiarization walk-throughs were not performed in accordance with the established plant instruction.

This is a Severity Level IV (Supplement II).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: _____

8407180026 840703
PDR ADOCK 05000390
0 PDR