

From: Leslie Perkins
Sent: Wednesday, August 13, 2008 2:52 PM
To: 'Peters, Robert (GE Infra, Energy, Non-GE)'; 'Honma, George (GE Infra, Energy, Non-GE, Us)'
Subject: Withdrawal of RAI 14.3-219 S02

Bob/George,

By letter dated July 18, 2008, we sent you the following request for information(RAI) regarding RAI 14.3-219 Supplement 2:

In response to RAI 14.3-219, GEH had provided ITAAC #9 in DCD, Tier 1, Table 2.16.2-6 to test and verify that the dedicated portable AC generator(s) are available on site, and are capable of providing post 72-hour power to the Emergency Filtration Unit (EFU) fan system. However, later information (GEH response to RAI 9.4-31, MFN 08-343) showed that GEH had replaced the “small portable AC generator(s) dedicated to the EFU fan systems” by “two installed ancillary diesel generators with more expanded RTNSS role.” So, the post 72-hr backup power to each EFU fan system will rather be provided by the ancillary diesel generators. In response, the staff asked GEH (RAI 14.3-219 S01) to provide an ITAAC to verify the on-site ancillary diesel generators performance capabilities to provide post 72-hr power to the EFU fan system and other RTNSS loads. Though GEH has rightfully deleted ITAAC #9 in DCD, Rev. 05, Tier 1, Table 2.16.2-6 about portable AC generator(s), it has not provided an ITAAC for the two ancillary diesel generators. Please provide the ITACC, or justify its exclusion.

We have determined that GEH has addressed RAI 14.3-219 S02 by including inspections, tests, analyses, acceptance criteria (ITAAC) for ancillary diesels in Tier 1, Table 2.13.4-2 of Revision 5 of the DCD. Therefore, staff is withdrawing RAI 14.3-219 S02 and you do not need to submit a response.

Please contact me if you have any questions,

Leslie Perkins
Project Manager
Division of New Reactor Licensing
Office of New Reactors
U.S. Nuclear Regulatory Commission
301-415-2375