

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1630 Chestnut Street Tower II

85 SEP 30 A 8:50

September 25, 1985

WBRD-50-390/82-01

WBRD-50-391/82-01

U.S. Nuclear Regulatory Commission
Region II

Attn: Dr. J. Nelson Grace, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Dear Dr. Grace:

WATTS BAR NUCLEAR PLANT UNIT 2 - EXCESSIVE MOVEMENT OF CONTAINMENT PENETRATION
BELLOWS - WBRD-50-390/82-01 AND WBRD-50-391/82-01 - SUPPLEMENT TO FINAL REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on December 4, 1981 in accordance with 10 CFR 50.55(e) as NCR
WBN CEB 8119. Interim reports were submitted on January 8, March 16,
August 4, and December 2, 1982 and May 18, 1983. Our final report was
submitted on October 3, 1983. This constitutes our supplemental final report.

Report Supplement

The date of June 30, 1985 for completion of corrective actions indicated in
our supplemental final report on this matter was not met. As stated in our
final report on this item, actions needed for unit 2 were to be performed
under engineering change notice (ECN) 3645. This was based on the fact that
the analysis problems for unit 2 were opposite hand to the unit 1 problems
cited in our final report. In 1984, TVA completely revised its analysis
program for unit 2 piping and supports and, as part of this change, the scope
of ECN 3645 was revised to omit all unit 2 work. New analyses were performed
for all unit 2 piping and new isometrics were generated. Because of this, the
unit 2 work originally mentioned in our final report is now being completed as
part of the overall programmatic changes being accomplished for unit 2 using
various ECNs. This work will be completed per the revised unit 2 schedule and
no later than unit 2 fuel load.

8511120401 850925
PDR ADOCK 05000391
S PDR

U.S. Nuclear Regulatory Commission

September 25, 1985

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. W. Hufham
J. W. Hufham, Manager

Licensing and Risk Protection

cc: Mr. James Taylor, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339