

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA TENNESSEE 37401

400 Chestnut Street Tower II

2 111 22 48:13

July 19, 1982

WBRD-50-390/81-53
WBRD-50-391/81-51

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3'00
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - CLASS IE ELECTRICAL COMPONENTS
FOR ERCW TRAVELING SCREENS - WBRD-50-390/81-53, WBRD-50-391/81-51 -
SUPPLEMENTAL INFORMATION


The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on May 18, 1981 in accordance with 10 CFR 50.55(e) as NCR
WBN NEB 8112. Interim reports were submitted on July 17 and August 3,
1981, and February 23, 1982. Our final report was submitted on April 9,
1982.

As discussed with NRC-OIE Inspector J. D. Wilcox on June 29, 1982, the
date of June 6, 1982, for completion of corrective actions indicated in
our final report on this matter was not met because TVA was unable to
obtain documentation to qualify the motors. The motors will be replaced.
The corrective action on this matter will be completed by March 1, 1983.

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

OFFICIAL COPY

8207270104 820719
PDR ADOCK 05000390
S PDR