

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA TENNESSEE 37401

400 Chestnut Street Tower II

July 28, 1982

2 50

WBRD-50-390/81-36

WBRD-50-391/81-35

U.S. Nuclear Regulatory Commission

Region II

Attn: Mr. James P. O'Reilly, Regional Administrator

101 Marietta Street, Suite 3100

Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - ANCHOR BOLTS INSTALLED NOT IN ACCORDANCE WITH SPACING SPECIFICATIONS - WBRD-50-390/81-36, WBRD-50-391/81-35 - NINTH INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector R. V. Crlenjak on March 31, 1981 in accordance with 10 CFR 50.55(e) as NCR SWP 8106. Interim reports were submitted on April 30, May 21, June 4, September 16, and December 2, 1981 and January 29, April 13, and May 24 1982. We expect to provide additional information on or about September 23, 1982.

TVA is currently reviewing the design of engineered support base plates with self-drilling expansion shell (SSD) anchors spacings that are less than required by G-32 revision 6. These base plates are also being reviewed for reduced spacings to adjacent base plate SSD anchors that were allowed by drawing 47A050-17.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

DS Kammer

for L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8208050420 820728
PDR ADOCK 05000390
S PDR

OFFICIAL COPY

IE 27