TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

August 9, 1982

WBRD-50-390/82-11
WBRD-50-391/82-11

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - DESIGN OF HVAC PENETRATIONS IN CONTAINMENT - WBRD-50-390/82-11, WBRD-50-391/82-11 - THIRD INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector R. V. Crlenjak on December 24, 1981 in accordance with 10 CFR 50.55(e) as NCR WBN CEB 8120. Interim reports were submitted on January 28 and April 28, 1982. We expect to submit our next report by December 13, 1982.

TVA is continuing to reevaluate nonprocess penetrations using the correct load definitions. Any penetrations which are overstressed as a result of these loads will be supported by hangers or stiffened as required to qualify them according to the ASME Code Section III maximum allowable criteria.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

D S Kammer

for L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

OFFICIAL COPY

I627

8208120246 820809
PDR ADOCK 05000390
S PDR