

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1630 Chestnut Street Tower II

June 12, 1985

WBRD-50-391/84-19

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Dr. J. Nelson Grace, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Dear Dr. Grace:

WATTS BAR NUCLEAR PLANT UNIT 2 - OVERSTRESSED PAD PLATES FOR HYDROGEN PIPE  
SUPPORTS - WBRD-50-391/84-19 - SECOND INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector Bob Carroll on April 5, 1984 in accordance with 10 CFR 50.55(e) as NCR WBN CEB 8406. Our final report for unit 1 and first interim report for unit 2 was submitted on May 4, 1984. Below is our second interim report for unit 2. We expect to submit our next report on or about January 17, 1986.

Interim Progress

The drawings for the two unit 2 pad plates are being revised through engineering change notices (ECNs) 2104 and 5305, and will incorporate the stiffening that is required to qualify the pads.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. A. Damer*  
W. W. Hufham, Manager  
Licensing and Regulations

cc: See page 2

8507160737 850612  
PDR ADOCK 05000391  
S PDR

05 JUN 18 10:05

*Te 27/0*

Dr. J. Nelson Grace

June 12, 1985

cc: Mr. James Taylor, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute Of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339