

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

July 14, 1983

U.S. Nuclear Regulatory Commission
Region II
ATTN: James P. O'Reilly, Regional Administrator
101 Marietta Street, NW
Suite 2900
Atlanta, Georgia 30303

83 JUL 26 P 1 : 58
USNRC REGION II
ATLANTA, GEORGIA

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - NRC-OIE REGION II INSPECTION REPORT
50-390/82-20 AND 50-391/82-20 - FOURTH SUPPLEMENTAL RESPONSE TO DEVIATION
390,391/82-20-01 AND SUPPLEMENTAL RESPONSE TO DEVIATION 390,391/82-20-02

The subject inspection report cited TVA with four deviations. Our responses were submitted December 16, 1982. Supplemental responses to deviation 390,391/82-20-01 were submitted on January 31, April 11, and May 9, 1983. This constitutes our fourth supplemental response and supplemental response to deviations 390,391/82-20-01 and 390,391/82-20-02, respectively.

As discussed with NRC-OIE Inspector Linda Watson on June 30, 1983, the date of June 30, 1983, for completion of corrective actions indicated in our previous reports on deviations 390,391/82-20-01 and 390,391/82-20-02 was not met.

Acceptance of the two fire dampers necessary for completion of the corrective action for deviation 82-20-01 has been delayed due to questions concerning acceptability of 1- by 1- by 3/16-inch angle iron used in their installation. The angle iron has been determined to be acceptable as is and corrective actions were completed as of July 6, 1983.

Corrective action for deviation 82-20-02 was not completed by June 30, 1983, as problems with the fire damper instruction drawings delayed damper inspections. These problems involve a difference of interpretation of the drawing instructions between engineering and inspection personnel as well as problems following required sleeving instructions. These problems are being resolved and all corrective actions will be complete by September 30, 1983.

U.S. Nuclear Regulatory Commission

July 14, 1983

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

To the best of my knowledge, I declare the statements contained herein are complete and true.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339