

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.3 -----NOTES-----</p> <ol style="list-style-type: none"> 1. DG loadings may include gradual loading in consideration of manufacturer's recommendations. 2. Momentary transients outside the load range do not invalidate this test. 3. This Surveillance shall be conducted on only one DG at a time. 4. This SR shall be preceded by and immediately follow without shutdown a successful performance of SR 3.8.1.2 or SR 3.8.1.6. <p>-----</p> <p>Verify each DG is synchronized and loaded and operates for ≥ 60 minutes at a load:</p> <ol style="list-style-type: none"> a. Unit 1; ≥ 2500 kW; and b. Unit 2; ≥ 5100 kW and ≤ 5300 kW. 	<p>31 days</p>
<p>SR 3.8.1.4 Verify fuel oil level above lower limit switch in each day tank.</p>	<p>31 days</p>
<p>SR 3.8.1.5 Verify the fuel oil transfer system operates to transfer fuel oil from storage tank to the day tank.</p>	<p>31 days</p>