RAS M_194

NEC-JH_22

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Vermont Yankee Nuclear Power Station

SUBJECT: SUMMARY OF MEETING HELD ON JANUARY 8, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION STAFF AND ENTERGY NUCLEAR OPERATIONS, INC. REPRESENTATIVES TO DISCUSS THE RESPONSE TO A REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

On January 8, 2008, the Nuclear Regulatory Commission staff (the staff) met with members of Entergy Nuclear Operations, Inc. (the applicant) in a public meeting to discuss the response to a request for additional information (RAI) made by the staff pertaining to the Vermont Yankee Nuclear Power Station (VYNPS) license renewal application. The applicant had an opportunity to comment on this summary.

A list of attendees is provided in Enclosure 1. The meeting agenda is provided in Enclosure 2. Comments made by the public during the meeting are provided in Enclosure 3. A copy of the slides presented by the applicant is provided as Enclosure 4. A summary of the discussion follows:

Background

In a letter dated November 27, 2007, the staff issued RAI 4.3.3-2 to the applicant. The purpose of the request was to gather additional information on the calculations used at VYNPS to reanalyze their time-limited aging analysis (TLAA) that addresses environmentally-assisted fatigue. In a letter dated December 11, 2007, the applicant provided its response to RAI 4.3.3-2 to the staff. The staff reviewed the response and further questioned the methodology described in the submittal and statements made that shear stresses are negligible during a conference call with the applicant on December 18, 2007. During the call, the applicant requested a face-to-face meeting to ensure that its position pertaining to this highly technical issue was properly and effectively communicated.

Discussion

During the meeting, the applicant made a slide presentation of the reactor vessel nozzle environmental fatigue analyses for license renewal at VYNPS. The applicant reviewed the terminology used in the response to RAI 4.3.3-2. The applicant reviewed the analyzed vessel nozzle configurations to identify where the shear stresses in the nozzles were negligible, where they were not, and the effects on the fatigue analysis at the locations where shear stresses were not negligible.

U.S. NUCLEAR REGULATORY COMMISSION

n the Matte	rd Enterry	Nucleur Vermon	Yanny LLL
Docket No.	50-271	Official Exhibit	NO. NEL-SH-22
OFFERED L	by: Applicant/Lic	ensee (niervenn)	NEL
	NRC Staff	1.4m 	
DENTIFIED	on7/210	Sector Caller L	Lopinfeld
ction Teles	ADMITTED	REJECTED	WITHDRAMM
enonedCa	M MA	C	

DOCKETED USNRC

August 12, 2008 (11:00am)

OFFICE OF SECRETARY RULEMAKINGS AND ADJUDICATIONS STAFF

Inplate sleep-028

NEC072277

DL-03

The applicant explained that nozzle corner, blend radius, and inner radius are interchangeable terms for locations with geometrical discontinuities; that is, locations where stresses are maximum. The applicant explained that the methodology employed incorporates the use of axisymmetric modeling rather than an exact configuration 3-Dimensional (3-D) or 2-Dimensional (2-D) modeling. They explained that axisymmetric modeling is a 3-D model except that it models the nozzle/vessel interface as a sphere with a multiplier to account for pressure stress effects, rather than a pipe joined to a cylinder. With the aid of colored graphs, the applicant demonstrated specific nozzles where shear stresses are negligible. The applicant also discussed the various conservatisms used in their analysis.

Conclusion

1. Based on the analyses performed, the applicant presented its conclusion that the effects of shear stresses were negligible or were separately addressed for all nozzles analyzed.

2. Based on its interaction with the NRR staff during the meeting, the applicant agreed to perform additional confirmatory work and submit results to the staff for review and acceptance. This work effort will include:

- Performing benchmarking calculations on the feedwater nozzle, which is the most limiting component, using the axisymmetric finite element model, taking fully into account all stress components on the nozzle and using the ANSYS FEM computer code to model all defined transients;
- 2) Demonstrating that the Vermont Yankee specific benchmarking calculations bound the results for the Core Spray and Recirculation outlet nozzles.
- 3) Calculating fatigue usage factors (CUFs) using NRC approved ASME Section III NB-3200 methods; and
- Comparing the resulting CUFs to the previous environmental assisted fatigue calculations to establish whether the previous calculations are adequate.

Jonathan G. Rowley, Project Manager Projects Branch 2 Division of License Renewal Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:

. .

. 1

.

.]

....

Attendance List
Agenda
Public Comments
Presentation slides

cc w/encls: See next page

Jonathan G. Rowley, Project Manager Projects Branch 2 Division of License Renewal Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:

1. Attendance List

2. Agenda

3. Public Comments

4. Presentation slides

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.:

DOCUMENT NAME: G:\ADRO\DLR\RLRB\ROWLEY\Meeting with VY-Entergy Summary – January 8, 2008.doc

OFFICE	LA:DLR	PM:RPB2:DLR	BC:RPB2:DLR	BC:RERT:DLR
NAME		JRowley	RFranovich	KChang
DATE	1 1	1 1	/ /	1 1

OFFICIAL RECORD COPY

MEETING BETWEEN THE NRC STAFF AND ENTERGY NUCLEAR OPERATIONS, INC. VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

6003 EXECUTIVE BOULEVARD ROOM EBB1B15 ROCKVILLE, MARYLAND

MEETING ATTENDANCE LIST JANUARY 8, 2008

PARTICIPANTS	AFFILIATIONS
Jonathan Rowley	U.S. Nuclear Regulatory Commission (NRC)
Samson Lee	NRC
John Fair	NRC
Kenneth Chang	NRC
PT Kuo	NRC
Rani Franovich	NRC
Robert Sun	NRC
Qi Gan	NRC
Kaihwa Hsu	NRC
Ricardo Rodriguez	NRC
Mary Baty	NRC
Perry Buckberg	NRC
Evelyn Gettys	NRC
Yeon-Ki Chung	NRC
Peter Wen	NRC
On Yee	NRC
Gary Hammer	NRC
David Mannai	Entergy Nuclear Operations, Inc. (Entergy)
John McCann	Entergy
Jay Thayer	Entergy
Matias Travieso-Diaz	Entergy
Michael Metell	Entergy
Garry Young	Entergy
Norm Rademacher	Entergy

. .

Enclosure 1

NEC072281

~5~

Alan Cox

Entergy

PARTICIPANTS James Fitzpatrick Scott Goodwin John Dreyfuss Gary L. Stevens Terry. J. Herrmann Joe Hopenfeld David Lochbaum THE FOLLOWING PARTICAPATED AFFILIATIONS Entergy Entergy Structural Integrity Associates Structural Integrity Associates New England Coalition (NEC) Union of concerned Scientist VIA TELEPHONE BRIDGELINE

Sarah Hoffman John Sipos Paul Eddy Joan Leary Matthews Blaise Constantakes Rudolf Hausler **Raymond Shadis** Claire Chang **Ulrich Witte** Ed Anthes **Rich Schaller** Chalmer Myer **Bob Audette** Susan Smallheer Sally Shaw Fred Mogolesko

Vermont Department of Public Service New York Office of the Attorney General NEC NEC NEC Nuclear Free Vermont Strategic Teaming and Resource Sharing Southern Nuclear Operating Company The Brattleboro Reformer The Rutland Herald

Entergy

MEETING BETWEEN THE NRC STAFF AND ENTERGY NUCLEAR OPERATIONS, INC. VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

6003 EXECUTIVE BOULEVARD ROOM EBB1B15 ROCKVILLE, MARYLAND

AGENDA

~6~ ·

JANUARY 8, 2008

I.	Introduction and opening remarks	10 minutes
II.	Discussion of Response to Request for Additional Information (Response to RAI 4.3.3-2)	80 minutes
111.	Public Comments	30 minutes

IV. Adjourn

• •

. 1

Enclosure 2

NEC072283

~7~

MEETING BETWEEN THE NRC STAFF AND ENTERGY NUCLEAR OPERATIONS, INC. VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION ROCKVILLE, MARYLAND ROOM EBB1B15

MEETING MINUTES JANUARY 8, 2008

In a letter dated November 27, 2007, the staff issued RAI 4.3.3-2 to the applicant. The purpose of the request was to gather additional information on the calculations used at VYNPS to reanalyze their time-limited aging analysis (TLAA) that addresses environmentally-assisted fatigue. In a letter dated December 11, 2007, the applicant provided its response to RAI 4.3.3-2 to the staff. The staff reviewed the response and further questioned the methodology described in the submittal and statements made that shear stresses are negligible during a conference call with the applicant on December 18, 2007. During the call, the applicant requested a face-to-face meeting to ensure that its position pertaining to this highly technical issue was properly and effectively communicated.

Discussion

During the meeting, the applicant made a slide presentation of the reactor vessel nozzle environmental fatigue analyses for license renewal at VYNPS. The applicant reviewed the terminology used in the response to RAI 4.3.3-2. The applicant reviewed the analyzed vessel nozzle configurations to identify where the shear stresses in the nozzles were negligible, where they were not, and the effects on the fatigue analysis at the locations where shear stresses were not negligible.

The applicant explained that nozzle corner, blend radius, and inner radius are interchangeable terms for locations with geometrical discontinuities; that is, locations where stresses are a maximum. The applicant explained that their methodology incorporates the use of axisymmetric modeling rather than an exact configuration 3-Dimensional (3-D) or 2-Dimensional (2-D) modeling. They explained that axisymmetric modeling is a 3-D model except that it models the nozzle/vessel interface as a sphere with a multiplier to account for pressure stress effects, rather than a pipe joined to a cylinder. With the aid of colored graphs, the applicant demonstrated specific nozzles where shear stresses are negligible. The applicant also discussed the various conservatisms used in their analysis.

Conclusion

1. Based on the analyses performed, the applicant presented its conclusion that the effects of shear stresses were negligible or were separately addressed for all nozzles analyzed.

Enclosure 3

2. Based on its interaction with the NRR staff during the meeting, the applicant agreed to perform additional confirmatory work and submit results to the staff for review and acceptance. This work effort will include:

- Performing benchmarking calculations on the feedwater nozzle, which is the most limiting component, using the axisymmetric finite element model, taking fully into account all stress components on the nozzle and using the ANSYS FEM computer code to model all defined transients;
- 2) Demonstrating that the Vermont Yankee specific benchmarking calculations bound the results for the core spray and recirculation outlet nozzles.
- 3) Calculating fatigue usage factors (CUFs) using NRC approved ASME Section III NB-3200 methods; and

4) Comparing the resulting CUFs to the previous environmental assisted fatigue calculations to establish whether the previous calculations are adequate

Enclosure 3