

(1) Maximum Power Level

PSEG Nuclear LLC is authorized to operate the facility at a steady state reactor core power level not in excess of 3459 megawatts (one hundred percent of rated core power).

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 289, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Deleted Per Amendment 22, 11-20-79

(4) Less than Four Loop Operation

PSEG Nuclear LLC shall not operate the reactor at power levels above P-7 (as defined in Table 3.3-1 of Specification 3.3.1.1 of Appendix A to this license) with less than four (4) reactor coolant loops in operation until safety analyses for less than four loop operation have been submitted by the licensees and approval for less than four loop operation at power levels above P-7 has been granted by the Commission by Amendment of this license.

(5) PSEG Nuclear LLC shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Safety Analysis Report, and as approved in the NRC Safety Evaluation Report dated November 20, 1979, and in its supplements, subject to the following provision:

PSEG Nuclear LLC may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

REFUELING OPERATIONS

DECAY TIME

LIMITING CONDITION FOR OPERATION

---

3.9.3 The reactor shall be subcritical for at least:.

- a. 80 hours
- b. 168 hours

APPLICABILITY: Specification 3.9.3.a - From October 15<sup>th</sup> through May 15<sup>th</sup>, during movement of irradiated fuel in the reactor pressure vessel.

Specification 3.9.3.b - From May 16<sup>th</sup> through October 14<sup>th</sup>, during movement of irradiated fuel in the reactor pressure vessel.

ACTION:

With the reactor subcritical for less than the required time, suspend all operations involving movement of irradiated fuel in the reactor pressure vessel. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

---

4.9.3 The reactor shall be determined to have been subcritical as required by verification of the date and time of subcriticality prior to movement of irradiated fuel in the reactor pressure vessel.