

From: Marshall David
Sent: Friday, August 15, 2008 10:37 AM
To: patrick.simpson@exeloncorp.com
Cc: ken.nicely@exeloncorp.com; mitchel.matthews@exeloncorp.com; Matthew Hamm; Robert Elliott; Russell Gibbs
Subject: Application Accepted - Braidwood/Byron LAR to Administratively Clarify the OL & Tech Specs

Categories: Red Category

Pat,

By letter dated July 29, 2008, Exelon Generation Company, LLC (the licensee) submitted a license amendment request for Braidwood Station, Units 1 and 2, and Byron Station, Unit Nos. 1 and 2 (ADAMS Accession Number ML082120328). The requested amendment removes time, cycle, or modification-related items from the Operating Licenses and Technical Specifications (TSs) at both stations and proposes the correction of typographical errors introduced into the TSs at both stations in a previous amendment. The purpose of this message is to provide the results of the Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review was also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the Code of Federal Regulations (10 CFR), an amendment to the license (including the TS) must fully describe the changes requested and follow, as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and has concluded that it does provide technical information in sufficient detail to enable the NRC staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the NRC staff to complete its technical review, you will be advised by separate correspondence.

In accordance with our process as described in LIC-109, "ACCEPTANCE REVIEW PROCEDURES," I am placing a copy of this email in ADAMS as a publicly-available, official agency record.

Sincerely,
Marshall David
Senior Project Manager
(301) 415-1547

E-mail Properties

Mail Envelope Properties (01BD2A1885C88F45A12CB413DEF03410683AF8DF04)

Subject: Application Accepted - Braidwood/Byron LAR to Administratively Clarify the OL & Tech Specs

Sent Date: 8/15/2008 10:37:15 AM

Received Date: 8/15/2008 10:37:15 AM

From: Marshall David

Created By: Marshall.David@nrc.gov

Recipients:

patrick.simpson@exeloncorp.com (patrick.simpson@exeloncorp.com)

Tracking Status: None

ken.nicely@exeloncorp.com (ken.nicely@exeloncorp.com)

Tracking Status: None

mitchel.matthews@exeloncorp.com (mitchel.matthews@exeloncorp.com)

Tracking Status: None

Matthew.Hamm@nrc.gov (Matthew Hamm)

Tracking Status: None

Robert.Elliott@nrc.gov (Robert Elliott)

Tracking Status: None

Russell.Gibbs@nrc.gov (Russell Gibbs)

Tracking Status: None

Post Office:

HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	16227	8/15/2008

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: