

Metal Bellows Corporation

CHATSWORTH, CALIFORNIA



CR 364 REPORT

f yr

HOSE ASSEMBLY

FLEXIBLE METAL - INSTRUMENTATION PER ASME SECTION III, CLASSES 2 AND 3

SEISMIC CATEGORY I





8202010369 811125 PDR ADDCK 05000327 PDR PDR

20960 Knapp Street • Chatsworth, California 91311 • U.S.A. • Telephone (213) 341-4900 • Telex 651-488

METAL Ballow CORPORA

TABLE OF CONTENTS

- I. Introduction
- II. QTP 73989 -

Qualification Test Procedure for Hose Assembly -Flexible Metal Per ASME Section III, Class 2

III. Report No. 5410-7197

Qualification Test Report on Hose Assembly -Flexible Metal Per ASME Section III, Class 2 P/N 73989, S/N 007 by

> Approved Engineering Test Laboratories 9551 Canoga Avenue Chatsworth, California 91311

METAL Bellow CORPORATION

1.0 INTRODUCTION

The objective of the Design and Generic Test Program has been to develop, refine, and prove a superior hose design that would readily pass conservative worst case conditions considering the ASME Boiler and Pressure Vessel Code, Section III, Subsection NA, NC, ND, and MC, as well as the practical application conditions.

Considering the various potential applications for instrumentation and cooling water lines, a worst case 2500 psig 700°F condition was picked for generic test confirmation of the hose. One universal design and size was resolved to meet all of the initial size and operating cases beginning at 125 psi, 180°F to the 2500 psig 700°F case.

A Design objective of 40 year life was set, defined as 2000 hot, pressurization and shutdown cycles, with vibration, seismic, proof, and burst tests, with appropriate inspection and Mass Spectrometer level leakage tests. Specific tests considering Code K_s factors, etc., were:

Hot/Pressurization/Deflection/Depressurization/Cycling

4000 cycles at 750 \pm 50°F consisting of pressurization to 2500 psi, move to a 5.00 inch diagonal deflected position in the X, Y and Z axes, depressurization, return to installed position and repeat.

Operational Vibration

One million total cycles were performed, equally divided between each of 3 axes, pressurized in the 5.00 inch fully deflected position at 5 to 100 Hz, swept at one octave per minute per the required response spectra, which developed 3 to 51 g's depending on frequency.

METAL Ballows CORPORATION

Seism.c

Tested per the required response spectrum, 1.5 to 16.5 g, which covers the majority of power plant locations in the United States. Biaxial tests were conducted (two axes simultaneously). The X-Z plane was tested for the three possible conditions; empty, filled with water, and finally filled with water and pressurized. The tests were then repeated for the Y-Z axis for a total of six tests of 45 seconds each. Note that the Z axis in which the most deflection occurs conservatively was tested twice.

Hydrostatic

After Mass Spectrometer leakage testing to insure that no leaks had developed, pressure was applied to specified proof conditions, 3750 psi for two minutes to verify integrity and lack of deformation. Burst pressure of 8750 psi was applied and held for two minutes to again verify structural integrity. Pressure was then increased for the actual failure test. Final failure was achieved on the second test after a test equipment failure at 11,200 psi. The final failure was not catastrophic. The braid-restrained hose simply leaked fluid when 11,200 psi was reached the second time.

Of six possible mounting configurations, the four shown on the installation drawing were evaluated for torsional load required to deflect (which relates directly to stress) and freedom to deflect under vibration and seismic conditions. The worst case, an unsupported "U" configuration was chosen for testing.

Material selection was based on the use of Inconel 625 for the hose and transition end tangents for the High Temperature High Pressure applications and those involving chlorides. Austenetic Stainless Steel is intended for low temperature and low pressure, non-chloride applications and for low stressed pressure boundry areas.

METAL Ballow CORPORATION

The central intent of the project was to produce a design appropriate for Nuclear use that is substantially superior to the design of normal aerospace quality hose. Five specific and interacting design concepts involving convolute end tangents and support components, were combined to assure uniform stress distribution and the ability to readily pass generic testing and assure safe general usage.

The reasons for success of the project are an N/NPT Stamp qualified supplier, intent on proper quality controls, the special design superior to aerospace hose, ASME quality material with proper processing and control of processing and proof of qualification based on a generic test that conservatively exceeds actual conditions.



METAL BELLOWS CORPORATION CHATSWORTH, CALIFORNIA

QTP 73989

QUALIFICATION TEST PROCEDURE

FOR

HOSE ASSEMBLY - FLEXIBLE METAL PER ASME SECTION III, CLASS 2

JOB NO. 11337

Engr. Project Engr. rom. Enge. Mgr. nb**ež** Q. A. Manager

No. of Pages 11

September 17, 1976

Rev. J March 10, 1977



ž

Date	Par	as Affacta	4	T T				
and Rev.	Revised	Added	Deleted	Remarks	Revised			
10/13/76 A	Cover, 5, 6	i		Changes to Paragraphs 4.4, 4.5, 4.6, and added Paragraph 4.7.	EAJ			
B	Cover, i, 3 5, 6, 7, 8 11	10		Changes to Para. 3.8, 4.4, 4.5, 4.6, Fig. 1, Fig. 2, Added figure 4, (Page 10) Page 11 was Page 10	EAJ			
11-9-76 C	Cover, i, 5, 6, and 10			Change Paragraphs 4.4, 4.5, 4.6, and Figure 4	EAJ			
12-1-76 D	Cover, i, 3, 5, 6, 8, 9			Change Paragraphs 3.8, 4.3, 4.5, 4.6, and Figures 3 and 4	EAJ			
1-17-77 E	Cover, i, 9, 10			Revised Figures 3 and 4.	EAJ			
1-25-77 F	Cover, i, 5, 6 & 10			Revised para. 4.5 and Fig 4.	EAJ			
2- 4- 77 G	Cover, i, 3, 6,9			Revised Paragraphs 3.8 and 4.6; added Paragraph 4.7. Revised fig. 3	EAJ			
2-25-77 H	Cover, i, 6 9			Revised Para. 4.5, Fig. 3	EAJ			
3-10-77 J	Cover, i,4, 6, 9			Revised Para. 3.10, 4.7 and Figure 3.	EAJ			
	х.							



1.0 SCOPE

۵

This document establishes the procedures Metal Bellows Corporation (MBC) shall follow to perform the qualification tests on the Hose Assembly - Flexible Metal per ASME Section III, Class 2, MBC P/N 73989, hereafter referred to herein as the "hose assembly".

2.0 APPLICABLE DOCUMENTS

2.1 American Society of Mechanical Engineers (ASME)

ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, Subsection NA, General Requirements.

ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, Subsection NC, Class 2 Components.

2.2 The Institute of Electrical and Electronics Engineers, Inc.

IEEE STD 344-1975 - IEEE Recommended Practices for Seismic Qualification of Class IE Equipment for Nuclear Power Generating Stations.

2.3 Military

MIL-P-27401, Class I, Pressurizing Agent, Gaseous Nitrogen

MIL-P- 27407, Pressurizing Agent, Gaseous Helium

MIL-C-45662, Calibration System Requirements

MIL-STD-810, Environmental Test Methods

2.4 Metal Bellows Corporation

CPS 3071, Leak Detecting Procedure

Drawing Number 73989, Hose Assembly - Flexible Metal per ASME Section III, Class 2

METAL Ballows COMPANY

3.0 ADMINISTRA TIVE DATA

3.1 Test Conditions

Unless otherwise specified, all measurements and tests shall be at "ambient" or "standard test" conditions as follows:

- a) Temperature: 55 to 85°F
- b) Pressure: 24 to 30 in Hg.
- c) Relative Humidity: 20 to 80%

3.2 Test Tolerances

Unless otherwise specified, the test tolerances shall be as specified in MIL-STD-810

3.3 Calibration

Instrument calibration shall be in accordance with MIL-C-45662, and all gages for hydrostatic tests shall be in accordance with ASME Section III, NC 6000.

3.4 Test Facility

The testing shall be performed at MBC and/or an outside commercial laboratory approved by MBC.

3.5 Support and Participation

MBC shall be responsible for conducting all tests and provide total monitoring of all outside tests. Cognizant MBC design and quality assurance personnel shall be notified of intent to test and the time of test.

3.6 Quantity to be Tested

One test specimen, Part Number 73989, shall be subjected to all tests described in paragraph 4.0.



3.7 Reason for Test

The tests shall be conducted to verify that the design meets the specification requirements and successful completion of the tests shall qualify the configuration for use in Nuclear power plant generating stations.

3.8 Test Sequence

The test shall be conducted in the sequence shown below:

	TEST SEQUENCE						
Test	DESCRIPTION	Applicable Paragraph					
1	Inspection	4.1					
2	Proof Pressure	4. 2					
3	Leakage	4.3					
4	Thermo and Operating Cycle Test	4.4					
5	Leakage	4. 3					
6	Operational Vibration Test	4.5					
7	Leakage	4. 3					
8	Seismic	4.6					
9	Leakage	4.3					
10	Hydrostatic Pressure	4.7					



QTP 73989

Page 4

3.9 Data Requirements, Reduction and Analysis Techniques

- A All data required by the section 4.0 procedures shall be recorded on the applicable testing laboratory test data sheets.
- B All data shall be witnessed by the test personnel and MBC witnessing personnel to the extent necessary to certify the test results.
- C Test data sheets for each test shall include as a minimum pertinent parameters, i.e., part numbers, serial numbers, date, time, verification of environmental conditions, test parameters, all required input/output/computed data and initials/stamp of operator and witnessing personnel.
- D Photographs as required to validate test setup.
- E Copies of plots of frequency vs. acceleration for the input and response accelerometers during the survey and for the response accelerometers during the vibration to verify the input for vibration test.
- F Justification for any deviation from the test procedure.

3.10 <u>Description of Test Specimen</u>

The hose assembly is a flexible metallic constructed configuration with a convoluted interior wall and a braided exterior. The hose is a nominal .44 inside diameter approximately 42.25 inches in length with 1/2 O. D. X.095 wall Tubestubs. The test sample shall include additional test sections on each end with standard "B" type nut assemblies, compatible for easy connections and for pressurizing.

4.0 TEST PROCEDURE

4.1 Inspection

Each hose assembly shall be examined for workmanship, material and process certifications, dimensional and interface requirements to MBC Drawing 73989. (Figure 3) The inspection results shall be recorded on the Inspection Check List (ICL).



Proof Pressure

Hydrostatic proof pressure the hose with an internal pressure of 5330^{+25} psig for a period of 10^{41} minutes. There shall be no evidence of permanent deformation or failure during the test or after release of the pressure.

Leakage

Install the hose assembly on the mass spectrometer such that the interior of the hose is exposed to the vacuum pressure of the mass spectrometer. Check the hose assembly for total leakage per CPS 3071, paragraph 3.2. The leakage shall not exceed 1 X 10^{-6} scc/sec of He.

4.4 Thermo and Operating Cycle

Install the hose assembly as shown in figure 4. The hose assembly shall then be placed in a chamber and the ambient temperature and fluid temperature shall be maintained at $700^{\circ}F\pm50^{\circ}F$. The hose assembly shall be cycled <u>4000 times</u>. A cycle is defined from installed position and pressurized at 2500 psig, hold for two (2) seconds minimum, move the movable end of the hose assembly to a equivalent position of +5.00 inches on a spherical radius in the X, Y, and Z axis, reduce the pressure in the hose assembly to 0 psig, and then return to the install position.

This exceeds the requirements of 2000 design cycles of ASME Boiler and Pressure Vessel Code, Section III, Class 2, 1974 Edition, through the summer of 1976 Addenda, and NC364).4.

At the conclusion of the above test, the hose assembly shall meet the leakage requirements of paragraph 4.3.

4.5 Operational Vibration

Install the hose assembly into a configuration as shown in Figure 4. with the fixed end of the hose assembly off the vibration table. The movable end shall be mounted on the test fixture on the vibration table to an equivalent position of -2.88 inches in the X axis, +2.88 inches in the Y axis, and -2.88 inches in the Z axis, which shall be subjected to the vibration levels. The hose assembly shall be pressurized with water to 2,500 psig, and close off the pressure source. Sine sweep the hose assembly from 5 to 100 HZ at one (1) octave ner minute for a total of 1/3 million (333, 334) cycles in each axis for a total of one (1) million cycles.

4.2

4.3

I	I	1	1	I	i	1	1	1	1		ſ	1	1	I	٠	(1	1
																++++	++++	
														+++-				
					1			Figu	re 2.									
	:+							or pl	1 780					1:11		1111		
							NI I	SU P/	177	27				+ + + +		++++	++++	
				+	MECH	ANIC	AL/I	row	INDUC	ED	BRA	ION		+++++	+++++			+ + + + +
																	+++++	
	+++++		+++++		Displa	acem	ent(SA)	CPS		· G's			****		trit		
				•••••						• -• -• -•	2 0	· · · · ·	• • • • • •	-+-+-++	+ + + +-			
				1::::	1	1.0		1.1.1.						111				
			++++++			85										1111		
	0	++	• • • • • • •	• • • • •	+	65			8				+ + + + +			++++		
									1.10		. 5_(++-+-	+ + + + + +	-++++++++++++++++++++++++++++++++++++++		
· 🖌 · · ·				1					1100		51.0	1111	1:1:1	++++				
- Ñ		+++++	++++++	+ • • • -	+ + +	• • • • • •	·• •	++++-		+ + + + + + + + + + + + + + + + + + + +		1111				1111		
02		F		1					+ + + + + + - + - + - + - + - + - + - +									+
- 11 -		+++++	+++++	+								11111						
- Z			1									+ + + + + + -		+++++		++++		
			XIII									11.1.1		1111				
	++++	++++		+ + +	1		+	-+-+-+-						1111				
-z					+			-+ +		++++		+ • • • •	+++++	++++				
11	1			1										++++		++++	+++++	
- 21				XIII	1						1	1111		111				
		++++	+++++		+	••••	+++++	++++-	++++	++++		+++++	++++	++++				
				1	L	+										++++		
				*****	N						1	1111	11111	1111				
				+++++		5												
				+++++	+					++++		++++		++++	+++++		+++++	++++
				****	1!													++++
		++++			1	+ +												
				++++	+			++++	+++++				+++++	++++			+++++	
				1111	1									++++				
***				1::::	1				11111	1111		11111	11111	1111				
			++++	1													0	
			10-	1	0		\cap	1	\mathbf{O}		$\Theta -$		() ++	1117	()	118	0	
		1.11		::::C			M										++++++	
			11::::		1							11111	11111				1	U.D.
+++++++++++++++++++++++++++++++++++++++		++++	+++++				++++					+++++		titt				
*****				111+1	1	1111	FRE	QUE	CY -	CPS!		1111	IIII				11.1	
	+++++				+++++				1111			11111					11111	TU
					1							+ + + + +				+++++	1:::::	. 8
******			* * * * *	++		••••			1111				1.111					
			+ -++++++-	+	++		+	+++++	+++++	+-+-+-+-+-	+	+ + + + +	+++++		1-1-1-1-	* * * * *	+++++	



ſ

.73989 .9



Fixed End



INSTALLED POSITION OF HOSE

Total free length of Hose is approximately 45 inches. Free length of hose less adapters, approximately 37 inches. Movable end to move \pm 2.88 inches motion in all planes. This meets the requirement of the movable end being capable of moving in a 5.0 inch spherical radius.

Moving from Position 1 to Position 2 may be in a straight line (-X, +Y, -Z)

Figure 4

TAL	Bellows CC	DMPAN	IY INSPE	CTION CHECK	LIST	•	QTP 7398" Page 11 REV: DATE:
ART No	73989		Rev	DESC	RIPTION		
OB No.	11337				\$	Lot	No Qty
[tem No	Dimension or Req.	Ťol.	Tool or Equipment Used	Reaults	Pcs. Acpt.	Pcs. Rej.	Remarks
						1	
						·	•
						•	
· · ·	···.		5.				
					-		·····
	-						
	•						
		·					
			· · ·				
Inspe Custo	ected merMBC	······		Date Gustomer	Q.C	\$	heet of
Inspe Custo Form	mer MBC			_ Date Gustomer	Q.C	S	heetof Date

Report No. 5410-7197	
P.O. No. 78054	
Date: 8 March 1977	
39 Page Report	

Test Report No. 5410-7197

Qualification Test Report

on

Hose Assembly - Flexible Metal per ASME Section III, Class 2

> Part Number 73989 Serial Number 007

TESTED FOR:

TESTED BY:

METAL BELLOWS CORPORATION 20977 Knapp Street Chatsworth, California 91311

APPROVED ENGINEERING TEST LABORATORIES 9551 Canoga Avenue Chatsworth, California 91311

	OFFICIAL SEAL
(main)	THERESA J. HAMPION
1.2.1	LOS AUCTIS COURT
	My comm. c plas APR 27, 1993

STATE OF CALIFORNIA COUNTY OF LOS ANGELES WILLIAM TRAW, Facility Manager denotes and says: That the information contained in this report is the result of complete and carefully conducted tests and is to the best of the hypowledge true and correct in all respects. suit of March 77 135, State of California.

FOR OUR MUTUAL PROTECTION, THE UP PART, FOR ADVERTISING OR PUBLIC APPROVALL THIS REPORT OTHER FOR

"THIS REPORT, COMPLETE OF IN

6:206

NTS

3

2

1.1

Report	No.	541(0-7197	-
Date:	8 Ma	arch	1977	

• • • • • • • • • • • • • • • • • • • •	
SIGNATURES	
Written By: Ball Chinedo Date: 3-	8-9-9
Approved By: M.D. Connell Date: 3- PROJECT MANAGER, M. Connell	9-77
Approved By:Approved By: Date: 3- QUALITY CONTROL MANAGER, Ray B. Hauke, P.E. Registered Professional Engineer, Chif.: QU 326	9-77
ĘŒ	<i>ŧ</i>

i



đ

5

Report No. 5410-7197

Date: 8 March 1977

TABLE OF CONTENTS

		Page No.
Signature Pa	ige	1
Table of Cor	ntents	· . 1 ···
1.0	PURPOSE	
2.0	REFERENCES	1.
3.0	SUMMARY	1
4.0	TEST CONDITIONS AND TEST EQUIPMENT	า่
4.1	Test Conditions	T
4.2	Test Equipment	ן <mark>ר</mark>
5.0	TEST PROCEDURES AND TEST RESULTS	13
5.1	Thermo and Operating Cycle Test	13
5.2	Helium Leakage Test	14
5.3	Operational Vibration Test	15
5.4	Leakage Test	16
5.5	Seismic Vibration Test	17
5.6	Burst Test	18
Photograph] - Typical Thermo and Cycling Test Setup	19
Photograph	2 - Operating Vibration Test Setup (X Axis)	20
Photograph	3 - Operating Vibration Test Setup (Y Axis)	21
Photograph	4 - Operating Vibration Test Setup (Z Axis)	22
Photograph	5 - Seiemic Vibration Test Setur (X and Z Avis)	23
Photograph	6 - Seismic Vibration Test Setup (Y and Z Axis)	24
Annondix 1	- X-Y Plots	2 5



<u>Report No. 5410-7197</u> Date: 8 March 1977

1.0 PURPOSE

The purpose of this report is to present the test procedures used and the test results obtained during the performance of a test program. The test program was conducted to determine conformance of one Flexible Hose Assembly, Part Number 73989, Serial Number 007, to the Qualification Test requirements specified in Reference 2.1 in accordance with Reference 2.2.

- 2.0 **REFERENCES**
- 2.1 Metal Bellows Company Document Number QTP 73989, Revision G, dated 4 February 1977. Title: Qualification Test Procedure for Hose Assembly - Flexible Metal
- 2.2 Metal Bellows Corporation Purchase Order Number 78054.

3.0 SUMMARY

- 3.1 One Metal Hose Assembly, Part Number 73989, Serial Number 007, has been subjected to the Qualification Test described in this report. During the test program, no anomalies were noted.
- 3.2 All results are presented for evaluation.
- 4.0 TEST CONDITIONS AND TEST EQUIPMENT
- 4.1 Test Conditions

Unless otherwise specified in this report, all tests were performed at room ambient conditions consisting of a temperature of $70\pm20^{\circ}$ F, a relative humidity of less than 95 percent and a barometric pressure of 29.92±2.0 inches of mercury absolute.

4.2 Test Equipment

The following test equipment was calibrated, as required, in accordance with MIL-C-45662A with traceability to the National Bureau of Standards. The NBS traceability records are maintained on file in the applicable AETL Quality Control office.



٤

APPROVED ENGINEERING TEST LABORATORIES

Report No. 5410-7197

Date: 8 March 1977

.....

4.2 <u>Test Equipment</u> (Continued)

4.2.1 <u>Thermo and Operational Cycle Test</u>

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

EllO5V Digital Thermometer John Fluke AC-DC2100A-01 13536 One year (Cal. Due 12-30-76) -320 to +1400°F; ±0.1°F

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy EllO8V Digital Thermometer John Fluke 2100A 30037 One year (Cal. Due 1-26-77) -320 to +1400°F; ±1.0°F

P247L Pressure Gauge Ashcroft 1279D None One month (Cal. Due 11-28-76) O to 5,000 psig; ±0.5%

P745V Pressure Gauge Helicoid None None Three months (Cal. Due 2-19-77)

P1069V Pressure Gauge U. S. Gauge 1818 None Six months (Cal. Due 4-20-77) O to 5,000 psig; ±0.5%

Ľ.

ļ

đ



Report No. 5410-7197 Date: 8 March 1977

4.2.2 Vibration Test

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy D501V Cathode Follower M. B. Electronics N504 B34 Six months (Cal. Due 3-3-77) 5 Hz to 10 KHz (Amplifier), 3 Hz to 3 KHz (Integrate); ±1.0%

D546V Accelerometer Endevco Corp. 2220C RA67 Six months (Cal. Due 1-28-77) 2 Hz to 10 KHz, 0 to 1,000 g; ±5.0%

D561V Logarithmic Converter Moseley 60D 838 Six months (Cal. Due 5-18-77) 0 to 60 db; ±0.5 db

D687V Charge Amplifier Endevco Corp. 2720 AE15 Six months (Cal. Due 5-13-77) 1 to 100 mv, 1 to 1,000 g; ±2.0%

D732V Vibration Exciter M. B. Electronics C50 None Prior to use

Report No. 5410-7197 Date: 8 March 1977

1....

4.2.2 <u>Vibration Test (Cont.)</u>

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy D768V Charge Amplifier Unholtz Dickie 8PMCVA None Six months (Cal. Due 5-24-77)

D923V X-Y Plotter Electronic Instruments 320 None Six months (Cal. Due 7-17-77) O to 50 vdc/inch; ±0.2%

D959V Power Amplifier M. B. Electronics T452 148 Prior to use 24 KW

E977V Electronic Counter Hewlett Packard None 5233L Six months (Cal. Due 2-3-77)

None Servo Programmer Unholtz Dickie SPA-7 None Prior to use



Report No. 5410-7197 Date: 8 March 1977

4.2.2

Vibration Test (Cont.)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Feriod Range and Accuracy None Sweep Sine Generator Unholtz Dickie OSC-1 None Prior to use

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

4.2.3

Thermo and Operating Cycle Retest

None

2246M4

HB96

Accelerometer

Endevco Corp.

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy Ell05V Digital Thermometer John Fluke AC-DC2100A-01 13536 One year (Cal. Due 1-4-78) -320 to +1400°F; ±0.1°F

Six months (Cal. Due 7-3-77)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument, Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

MI

EllO8V Digital Thermometer John Fluke 2100A 30037 One year (Cal. Due 1-26-77) -320 to +1400°F; 21.0°F

G588V Sequence Cycler AETL CP1 None N/A



Report No. 5410-7197

Date: 8 March 1977

4.2.3

Thermo and Operating Cycle Retest (Cont.)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy P745V Pressure Gauge Helicoid None None Three months (Cal. Due 3-18-77)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy P1084V Pressure Gauge Ashcroft 1.66 None Three months (Cal. Due 3-14-77) 0 to 3,000 psig; ±1.0%

4.2.4 <u>Helium Leakage Test</u>

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy V25L Mass Spectrometer CEC 24-120B 9096 Daily 5X10⁻¹¹ scc/second/division (100,000 division)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy V514V Vacuum Gauge Veeco GV-3SV 2424 Three months (Cal. Due 2-11-77) 1,000 to 1 microns of mercury; ±10%

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy V525V Helium Leak AVT Industries 73168 1316 One year (Cal. Due 12-13-77) 2.48X10-7 sccs; ±10%



Report No. 5410-7197 Date: 8 March 1977

4.2.4

Helium Leakage Test (Cont.)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

P946V Compound Pressure-Yacuum Gauge Ashcroft 1082AC None Three months (Cal. Due 2-22-77) 30 inches of mercury to 15 psig; ±0.25%

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy ENV659V Pressure Chamber KVI Test Labs None None N/A

4.2.5 <u>Seismic Vibration Test</u>

. .

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy D800V Hydraulic Actuator Shore Western 912-5.1-9-3-13 94054 Prior to use 10,000 pounds max.

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy D801V Servo Control Valve Moog 72-103 911 Prior to use

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy D817V Linear Variable Differential Transformer Collins SS-20A 155111 Prior to use 0 to ±4 ir.ches

Report No. 5410-7197 Date: 8 March 1977

4.2.5

Seismic Vibration Test (Cont.)

AETL Number Instrument M. nufacturer Mo.'el Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Hodel Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy D818V Linear Varizble Differential Transformer Collins LMT-719T31 Unknown Prior to use O to ±5 inches; ±0.5%

D932V Servo Controller Shore Western SC1329C None Prior to use O to 10 inch stroke; ±5.0%

D965V Hydraulic Actuator Shore Western 913-7.6-8-4-138 95063 Prior to use

D966V Servo Control Valve Moog 72-103 951 Prior to use

D991V X-Y Display Spectral Dynamics 13116 400 Six months (Cal. Due 4-16-77)

Report No. 5410-7197 Date: 8 March 1977



4.2.5

Seismic Vibration Test (Cont.)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Scrial Number Calibration Period Range and Accuracy D992V Shock Spectrum Analyzer Spectral Dynamics 13231 21 One year (Cal. Due 4-16-77) O to 100 volts, 1 Hz to 10 KHz

D993V Transient Memory Spectral Dynamics 13192 24 One year (Cal. Due 4-16-77)

D1007V Accelerometer Endevco Corp. 2262-25 DY64 One year (Cal. Due 3-16-77) O to 750 Hz; ±1.0%

D1008V Standard Accelerometer Endevco Corp. 2262-25 DY40 One year (Cal. Due 3-16-77) 1 to 25 g; ±1.0%

D1010V X-Y Plotter Spartan 575 976142 Six months (Cal. Due 2-17-77) 1 mv/inch to 10 v/inch; ±0.025%

ų



Report'No. 5410-7197 Date: 8 March 1977



4.2.5

The C

Seismic Vibration Test (Cont.)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

Ni 265

D1023V Signal Synthesizer Byrd Enterprises Unknown None Prior to use

E503V Storage Oscilloscope Tektronix 564 008387 Prior to use

E564V Time Base Plug In Unit Tektronix 3B3 006688 Six months (Cal. Due 7-5-77) 0.1 µsecond/div. to 2.5 second/div.; ±3.0%

E593V Recording Oscillograph Midwestern Instruments M1603-F 1553 Prior to use 0.070 to 170 inches/second

E637V Dual Trace Plug In Unit Tektronix 3Al 011750 Six months (Cal. Due 7-5-77) 10 mv/div. to 10 v/div.; ±3.0%

Report No. 5410-7197 Date: 8 March 1977



4.2.5

Seismic Vibration Test (Cont.)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

1

Filare

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy E1058V Servo Controller Shore Western SC1125SP None Prior to use O to 10 inch strokes; ±5.0%

G587V Tape Recorder Precision Instruments 214 112 Prior to use 3.25 or 7.5 inches/second; ±0.5 db

P700V Pressure Gauge Ashcroft Unknown None Three months (Cal. Due 3-10-77) 0 to 5,000 psig; ±1.0%

None Bridge Balance Calico X1-101 021 Prior to use

None Bridge Balance Calico X1-101 035 Prior to use

NTS

Report No. 5410-7197

Date: 8 March 1977

4.2.5 Seismic Vibration Test (Cont.)

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy

None DC Amplifier CIC 3101-D3P CH7 Prior to use

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy None DC Amplifier CIC 3101-D3P CHH Prior to use

4.2.6 Burst Test

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy P844V Pressure Gauge Helicoid 4-1/2W-20,000-2None Three months (Cal. Due 3-17-77) O to 20,000 g; $\pm 0.5\%$

AETL Number Instrument Manufacturer Model Number Serial Number Calibration Period Range and Accuracy N/A



!|

Sector a start

Nes

APPROVED ENGINEERING TEST LABORATORIES A NATIONAL TECHNICAL SERVICES CO.

Report No. 5410-7197 Date: 8 March 1977

13m 🚄

- 5.0 TEST PROCEDURES AND TEST RESULTS
- 5.1 Thermo and Operating Cycle Test

Reference 2.1, Paragraph 4.4

Date Performed: 18 January 1977

- 5.1.1
 - The specimen was installed in a test fixture as illustrated in Photograph 1. The specimen was placed in the test chamber. The chamber and fluid temperatures were increased to, and maintained at, $700\pm50^{\circ}$ F. The specimen was pressurized to 2500 psig. Starting in the normally-installed position, the movable end of the hose assembly was then moved to an equivalent position of +5.0 inches on a spherical radius in the X, Y, and Z axes. The pressure was then reduced to zero psig and the hose assembly was returned to the normally-installed position. This constituted one cycle.
- 5.1.2

A total of 4000 cycles was performed. Visual examination following 4000 cycles of testing revealed no damage or other adverse effects.



5.2

.

:1

i

1

1

Į.

-

Tite

l

Pat .. .

APPROVED ENGINEERING TEST LABORATORIES A NATIONAL TECHNICAL SERVICES CO.

Report No. 5410-7197 Date: 8 March 1977

Helium Lykage Test

Reference 2.1, Paragraph 4.3

Date Performed: 19 January 1977

5.2.1

The specimen was installed in a test chamber. The interior of the specimen was exposed to the vacuum pressure of the mass spectrometer. The outside of the hose assembly was flooded with helium gas. Total leakage measured was 2.64X10⁻⁷ sccs versus the maximum allowable of 1X10-6 sccs.

5.2.2

Visual examination following testing revealed no damage or other adverse effects.



5.3

APPROVED ENGINEERING TEST LABORATORIES

A NATIONAL TECHNICAL SERVICES CO.

Report No. 5410-7197 Date: 8 March 1977

Operational Vibration Test

Reference 2.1, Paragraph 4.5

Date	Started:	21	January	1977
Date	Completed:	31	January	1977

5.3.1

The specimen was installed in a test fixture and was mounted on the vibration exciter as illustrated in Photographs 2, 3, and 4. The specimen was pressurized to 2500 psig. The specimen was subjected to cycling over the frequency range of 5 to 100 to 5 Hz at a sweep rate of one octave per minute at an applied double amplitude of 1.0 inch up to a limiting value of 31 inches per second acceleration. Testing was performed in each of the three major orthogonal axes for totals of 333,388; 333,470; and 333,336 cycles for testing in the X, Z, and Y axes, respectively.

5.3.2

0 265

Visual examination following testing revealed no damage or other adverse effects.



Report No. 5410-7197 Date: 8 March 1977

5.4 Leakage Test

Reference 2.1, Paragraph 4.3

Date Performed: 1 Febr ary 1977

5.4.1

The specimen was installed in a test chamber. The interior of the specimen was connected to the vacuum of a mass spectrometer. The vacuum was maintained at 0.4 micron, maximum, as noted on the mass spectrometer.

5.4.2

Ī

27.3

5

States in

間 11 1

[]

2.

1265

The exterior of the specimen was flooded with helium gas. The leakage rate was measured and was 1.872X10-7 sccs versus the maximum allowable of 1.0X10-6 sccs.





5.5

ł

1:

1

1

1

Naus

Report No. 5410-7197

Date: 8 March 1977

Seismic Vibration Test

Reference 2.1, Paragraph 4.6

-Date Performed:

8 February 1977

- 5.5.1
- The specimen was rigidly mounted on a vibration test fixture as illustrated in Photographs 5 and 6. The specimen was subjected to test response spectrum (TRS) that exceeded the minimum of 2.0 percent critical damping curve of Figure 1 of Reference 2.1. The TRW was applied first along the Z and Y axis, biaxially, for a period of 45 seconds. During this period, the specimen was dry with no pressure applied. The specimen was then rotated 90 degrees to the Z and X axis and was subjected to the TRW for a period of 45 seconds with no pressure applied.
- 5.5.2 The testing described above was then repeated with the specimen filled with/water and unpressurized.
- 5.5.3 The testing described in Paragraph 5.5.1 was then repeated with the specimen filled with water and pressurized to 2500 psig.
- 5.5.4 Visual examination following testing revealed no damage or other adverse effects. The X-Y plots prepared during the above testing are presented in Appendix 1. During Seismic Vibration Testing, the outputs of the control and response accelerometers were recorded on an oscillograph. The oscillograph records are being forwarded to the customer under separate cover.



5.6.1

5.6.3

265

THE REAL

APPROVED ENGINEERING TEST LABORATORIES A NATIONAL TECHNICAL SERVICES CO.

Report No. 5410-7197 Date: 8 March 1977

5.6 Burst Test

Reference 2.1, Paragraph 4.7

Date Performed:

8 February 1977

The specimen was installed in a hydrostatic pressure test system. The specimen was filled with deionized water and was bled of all air.

5.6.2 The specimen was then pressurized to 3750 psig and the pressure was maintained for a period of one minute. The pressure was then increased to 8750 psig and was maintained for an additional one-minute period.

An attempt was then made to increase the pressure until rupture of the specimen occurred. At a pressure of 11,200 psig, the test system line developed a leak. The pressure was reduced to zero psig. The line was repaired. The specimen was refilled with water and the burst test was continued. At an applied pressure of 11,200 psig, a leak was noted at the connection of the flexible hose and fitting. Burst testing was terminated at this point.



1

REPORT NO. 5410-7197 PHOTOGRAPH 1 TYPICAL THERMO AND CYCLING TEST SETUP





2

1

REPORT NO. 5410-7197 PHOTOGRAPH 4 OPERATING VIBRATION TEST SETUP (Z AXIS)





REPORT NO. 5410-7197 PHOTOGRAPH 5 SEISMIC VIBRATION TEST SETUP (X AND Z AXIS)





]

REPORT NO. 5410-7197 PHOTOGRAPH 6 SEISMIC VIBRATION TEST SETUP (Y AND Z AXIS)





٠

1

1

ľ

1_

APPROVED ENGINEERING TEST LABORATORIES A NATIONAL TECHNICAL SERVICES CO. Report No. 5410-7197 Date: 8 March 1977

APPENDIX 1

X-Y Plots

RESPONSE ACCELERATION (G - PEAK)

26

1

		RESPONSE SPEC	TRA	
		TRS	EARTHQUAKE	
		SPECTRUM:	ACCEL. MAXI	1
j) ^Y		POLARITY	+ MAXI	
	10.	DAMPING:	2.5%	
		ANALYSIS		
		BANDWIDTH	120 FILTERS OCTAV	ε
		MJO NUMBER	5410-6992	
		ITEM:	HOSE ASSEMBLY FIX	. ONL
		P/N:	73988	
	1.0	S/N:		185
		AXIS:	HORIZONTAL	-
		DATE:	2/8/77	Date
		TIME:	1008	
		OPERATOR:	In.	8 Ma
				Ţ
	0.1	QTP 73989	FIGURE I	

14

•;;

. RESPONSE ACCELERATION (G

27

5 6 7 8 9 100. 7 8 9 LO . 2 5 678910 4 RESPONSE SPECTRA TRS EARTHQUAKE PEAK) SPECTRUM: ACCEL. MAN POLARITY + MAXI 2.5% DAMPING: 10. ANALYSIS BANDWIDTH 120 FILTERS OCTAVE MJO NUMBER 5410-6992 HOSE ASSEMBLY (FIX.ONLY ITEM: P/N: 73988 11.0 S/N: 007 AXIS: VERTICAL Report Date: 218/17 DATE: TIME: 8 March 1977 1008 OPERATOR: QTP 73989 FIGURE |

1.7.7.2

....

T. 10 . 76-11

1, 1

PEAK) ۰ RESPONSE ACCELERATION (G



Report No. 5410-7197 Date: 8 March 1977

FREQUENCY (HZ)

RESPONSE ACCELERATION (G - PEAK)

29



5.3

FREQUENCY (HZ)

RESPONSE ACCFLERATION (G - PEAK)

30

FREQUENCY (H7)

- RESPONSE
TRS
E.a.S
SPECTRUM
POLARITY
DAMOTHE
DAMPING:
·
ANALYSIS.
BANDWIDTH
MJO NUMBE
TTEM
TIEW:
•
P/N:
0 S/N:
•,
AVICA
ANIS:
DATE:
TIME :
ODEDATOD-
UPERATUR:
QTP 739
4

SPECTRA

1 ---- 2

TRS	EARTHQUAKE
CTRUM:	ACCEL. MAXI
ARITY	<u> </u>
PING:	2.5%
LYSIS DWIDTH	120 FILTERS OCTAVE
NUMBER	5410-6992
4:	HOSE ASSEMBLE DRY
	73988
5:	HORIZ. X
:	2-8-77
•	1125
ATOR:	Ant.
P 739 89	FIGURE I

Date:

8 March 1977

1

ĩ

RESPOYSE ACCELERATION (G ~ PEAK)

ŝ



ACCEL. MAXI 2.5% 120 FILTERS OCTAVE 5410-6992 HOSE ASSEMBLY DRY 73988 007 VERT. Z 2-8-77 1125 FIGURE |

14

8 March 1977

4 5 6 7 8 9 100. RESPONSE SPECTRA 3 2 5 6 7 8 9 10. 3 4 5 6 7 8 9 1.0 2 EARTHQUAKE TRS ACCEL MAXI SPECTRUM: POLARITY 2.5% DAMPING: 10. ANALYSIS 120 FILTERS OCTAVE BANDWIDTH 5410-6992 MJO NUMBER HOSE ASSEMBLY ITEM: 73988 P/N: S/N: ∞7 1.0 X AXIS AXIS: 2/8/77 DATE: 1134 TIME: OPERATOR: QTP 73989 FIGURE 1

1

WET NO PRESS.

Date:

8 March 1977

PEAK) • RESPONSE ACCELERATION (G PEAK) ٠ RESPONSE ACCELERATION (G



RESPONSE SPECTRA

UM:	ACCEL MAKI	- ^
TY	+ ACCEL MARI	_
G:	2.5%	- -
IS DTH.	120 FILTERS	OCTAVE
MBER	5410-6992	.
	HOSE ASSEMBL	WET WET
	73988	-
	<u></u>	-
	Z AXIS	
	2/8/77	- dete
	1134	_ ¤;
OR:	R.J.m.	- Nar:
73989	FIGORE	1 1977
		CONTRACTOR OF SHORE OF SHORE SHORE

1.41

ω

6 7 8 9 100. 4 6789'0. 67891.0 10. 1.0

T T T T

EARTHQUAKE TRS ACCEL MAXI SPECTRUM: POLARITY 2.5% DAMPING: ANALYSIS OCTAVE 120 FILTERS BANDWIDTH 5410-6992 MJO NUMBER WET 2500751 ITEM: HOSE ASSEMBLY 73988 P/N: S/N: 007 X AXIS: 2/8/77 DATE: TIME: 1340 1140 Pam **OPERATOR:** QTP 73989 FIGURE 1

19

Report No. 5410-/19/ Date: 8 March 1977

RESPONSE SPECTRA

1 1

RESPONSE ACCELERATION (G -

1 XV 2d

1

EARTHQUAKE TRS ACCEL MAXI SPECTRUM: + POLARITY 2.5% DAMPING: 10 ANALYSIS ton it list a 120 FILTERS BANDWIDTH 5410-6992 MJO NUMBER 1120 HOSE ASSEMBLY 2500 PSI ITEM: 73988 P/N: 0 H1.0 007 S/N: Z AXIS: 122 2/8/77 -11 DATE: 1340 TIME: 1140 P1.71 **OPERATOR:** FIGURE 1 QTP 73989 0.

2

4

2

4 5 6 7 8 9 1.0

7 8 9 10.

17.15

1

4 5 6 7 8 9 100.

RESPONSE SPECTRA

OCTAVE

UST

Date:

8 March 1977

PEAK)

•

RESPONSE ACCELERATION (G . PEAK)

3

:

1

36

FREQUENCY ("E)

			53数化图图:23255 42月10月38日第55			
	동성상은 카드라에서 안전 높을만 등 전문은 분동물을 분위해 관련을	NG C 24 FLAX (24 PLA 2 NG C 2		TRS	EARTHQUAKE	
la la constanta da Mundura stanta						
				SPECTRUM:	ACCEL MAKE	
				POLARITY	+	
				DAMPING:	2.5%	
				ANALYSTS		
				BANDWIDTH	120 FILTERS OC	TAVE
				MJO NUMBER	5410-6992	
				ITEM:	HOSE ASSEMBLE	uo PRE
				P/N:	73988	
			1.0	S/N:	∞ 7	
				AXIS:	<u> </u>	
				DATE :	2/8/22	
			adın ac səkət Səhədi səkət	TINE .	//58	
				00504T00 -		
				UPERATOR:	- Jon	
			0.1	QTP 73989	FIGORE	piz

· · · · ·

1----

.

.

RESPONSE ACCELERATION (G - PEAK)

2

1

:

1

I

	대학원은 영국 이상 전 가지가 가지 않기 같은 양태소 은 영수 문도구관 575년 1799 같은 방법 같은 것은 문구동 동물 566 1750 175				
김 (신강) 학생 (5호) (5호) (호호) (호호)	컶윭놣븜룅 HLTHN 또 馮을을 갖고 동도 파티		TRS	EARTHQUAKE	
				1	
			SPECTRUM:	ACCEL. MAXI	
			POLARITY	+	
			DAMPING -	2.5%	
indenda - da			ANALYETE	- Andrewski - A	
			BANDWIDTH	120 FILTERS	OCTAVE
		<u>연구구 포</u>	MJO NUMBER	5410-6992	
			ITEM:	HOSE ASSEMBLY	WET
			P/N:	73988	NO PRE
		1.0	S/N:	© 7	
			AXIS:	2	-
				9-8-77	
			TINE .	11 59	te:
			IIME:	1130	
			OPERATOR:	<u>P.q. m.</u>	Marc
			QTP 73989	FIGORE 1	7

4

ſ

Report No. 5410-7197 Date: 8 March 1977

ALTOPSE ALLELEATTON (G - PEAK)

38

- <u>5</u> t		
• E		
71	a san an ha latinin mirthann an the	
i		
•		
_ S i		
-		
1		A second a party over the second in the second second second and part of the second
-1		
1	eeloping: New: (유왕 대의 New 문 문)	
3		
- 1		
-		
÷		
		anter and an and a state and a
- 1		
- 1		
	All and it of more also internet the here of	
-		
71		
•		
-		
	the state of the second s	
-		
•		
•		
		anter fam in ferte farte later anter tant tant anter an en an en anter
		an a
		and the second
	- BELLET FRANKLISCH, BELLEN, SAMER EN LEIS AN	
7		
-		
5		
-		
•	- 오르 이 감가 지지 않는 것 같은 말을 했는 것이다. 두	
	er star per si hendral tala artiste da ta si	
•		
		and the second se
	REFEAL LITTS HISTORY WARTERS AN ATS SA 10	
	Constants and south and the state of the state of the state of the state of the	

57891.0

5

1 10.

RESPONSE SPECTRA

TRS

6789100.

ACCEL. MAXI SPECTRUM: + POLARITY 2.5% DAMPING: ANALYSIS 120 FILTERS OCTAVE BANDWIDTH 5410-6992 MJO NUMBER WET HOSE ASSEMBLY 2500PSI ITEM: 73988 P/N: S/N: 007 Y AXIS AXIS: 18/77 Date: 8 March 1977 DATE: 1202 TIME: **OPERATOR:** QTP 73989 FIGURE |

EARTHQUAKE

PEAK AESPONSE ACCELERATION (G .

39

FRI ONENCY (HZ)

5 6 7 8 9 100. 3 4 2 7 8 9 10. 672910 2 Ħ 10. 1.0

RESPONSE SPECTRA

TRS EARTHQUAKE

SPECTRUM:	ACCEL. MAXI
POLARITY	t
DAMPING:	2.5%
ANALYSIS BANDWIDTH	120 FILTERS OCTAVE
MJO NUMBER	5410-6992
ITEM:	HOSE ASSEMBLY NET
P/N:	_73988
S/N:	
AXIS:	<u>z</u> ^
DATE:	2-8.77
TIME:	<u></u>
OPERATOR :	Hard
QTP 73989	FIGURE

Report No. 5410-7197 Date: 2 March 1977



CR 434

APPENDIX II CR 431

SUPPLEMENTAL STRESS REPORT



٠

ADDENDUM I TO CR 364

HOSE ASSEMBLY FLEXIBLE METAL - INSTRUMENTATION PER ASME SECTION III, CLASSES 2 AND 3 SEISMIC CATEGORY I

R. H. Ny Krom, Project Engineer

W. D. Coodey, Chief Engineer

P. B. Campbell, Director of Engrg.

٩

No. of Pages 5

February 24 , 1978



2.0

Addendum I CR 364 Page 1

- 1.0 This Addendum to Test Report CR 364 is to provide justification for MBC's use of P/N 73989 in the "U" configuration for qualification testing and to show that the tube ends meet the allowable stress requirements of the ASME B & PV Code, Section III, Para. NC 3650 (Piping System Analysis).
 - The major portion of the loads imposed on the hose end are caused by the friction between the braid and hose, which is caused by the squeezing effect of the braid because of end load. End load is a direct function of pressure.

With the hose in the various recommended installed positions, and pressurized to the maximum design pressure (2500 psig), the loads (force and moment) were measured to displace one end (opposite and fixed) of the hose through the various displacements. The loads were recorded at the maximum displacements.

The loads were non-linear, i.e., a minimum force was required to start the hose moving; then very little extra load was required to maintain the motion of the end until maximum deflection was reached. This deflection load would remain until the end was deflected slightly (.01 - .06 in) in the opposite direction. Also, the rate of change (different velocities) did not affect the load required. Note: With zero pressure, the forces required to displace the hose were so low, that they could not be measured with the equipment available in MBC's test laboratory.

To displace the moving end, a force was applied and at the same time a restoring moment was applied to maintain parallelism. The highest force to deflect the hose 5 inches was 18 lb. The highest moment applied was 9 ft-lbs. Most loads and moments were 6 - 10 lbs. and 5 - 7 ft-lbs. These moments were measured at the "B" nut coupling used for test purposes, which is the same point where the connecting socket weld would be located.

The selection of the "U" configuration for seismic testing was based on the following reasons:

- 1. It provided the floppiest configuration under seismic excitation; and because of the ease of deflection, it is MBC's contention that this was definitely a "worst case" test.
- This configuration generated the highest moment loads on the hose as stated above.

B.H. CORDER	ENGINEER	REFERENCE NUMBER	
METAL CORPORATION 20977 KNAPP STREET CHATSWORTH, CALIFORNIA 91311	DATE 2-15-73	CUSTOMEN BECHTEL	PAGE OF
3 REQUIREMENTS	OF NC	3659	
3.1. CALCULATIONS K	EQUIRED		2003 - 100 A
2.1.1 WEIGHTS	1(()) () (02(11 (3/)) -	3657
HOSE: ((70-5	(-37) (30) (-	Tr (.49) (01.)(3) =	817 = 050
BRAID: .215	LS/ X 3FT		645
SPRING: Tr (.89)	1.093)2.7854	(45)(.3) =	.274
ADDITOR: (.72	47 ²)(.72)(.78	(.3) =	.046
TUBE : (.52-	.317)(2.2)(.7	854)(.3) =	.080
FERRULE: (.05)	(1.5)(1.059)1	r (.3) =.	.075
3.1.2 MOMENT (D	FOR HOS	CONSERVITISM SE IS STRAIGH LENGTH OF TO	TAL WITH .5 S
M. (HOSE) = SUPERIOSHION)	$\frac{\omega l^2}{2} = \frac{.050}{.050}$	os /(20.75) ² -(2.5) ³ 2	1 = 10.61
M2 (FERRULE) -	W. 2 = (075)(2.75)	21
M; (70BE)=	<u>we</u> = (.6	080)(.5)(2.5)	10
Mu (NOPPTOR)	- N.C = (.C	240) (2.5 + (.5%)	13
NIS (SPRING)	W.C = (.e		ଧ୍ୟ = 1.3 0
	TOTA	L MOMENT	= 12.42
3.1.3 SA = f (1.25 S.	+025 5%)	(REF NC .3611.	2 Gg(C))
3.1.3 SA = f (1.25 S. = 1 [1.25 (13	+.25 54) (15) +.25(15	(REF NC - 3611. 5.1)] = 27.1 Kg	2 Cq(C)) (@ 7,000

Ru	ENGINEER RAIVETEDE	REFERENCE NUMBER	100.01
METAL Dation CORPORATION	PATE DATE	CUSTOMER	PAGE OF
20977 KNAPP STREET Chatsworth, California 91311	2-15-78	BECHIEL	3
21.4 STUB END DA	ESCRIPTION	11 R CO 212 TO	2.2011
3.1.5 MATERIAL PROF.	VVIILL PER SERTIES PER	SECTION III O Kni	TABLE I-7.2
MIN ULT SALLOW	IMATE = 7	5 Kai 15.9 Kai @ 70	O'F CESISM TE
3.1.5 FRITIQUE ALLOW	VABLE PER	SECTION I	F16 I-9.2
SALLOW = 2	6 Ksi for	10 CYCLES	
(4	E = 26.0 X 10	»")	
3.2 SUSTAINED LO	nos (ref	NC-3652.1	Eq (3)
$\vec{f}_{SL} = \frac{PD_{o}}{4t_{n}} +$.75 ż N Z	na < 1.0 5h	
= <u>2500 (.5)</u> 4 (.093)	+ -75 (2.1 Tr (-20	1) (12.42) 35) ² (.093)	£ 1.0 (15.9 K
	L = STRESS	INTENSITY FOR	FILLET WE
	MAF DEMU	WEIGHT	
	$Z = T \Lambda_m^2$	t (REF NC3)	65 <i>2.4 (</i> Q))
= 3.36 Ka	+ 1.62 Kai	= 4,95 Ka 5= 13	5.9 Kat
	100	CALLOTE 1	



4.5 Operational Vibration (continued)

, The sweep cycling shall be at the displacements and G levels of Figure 2.

The pressure source shall be monitored during the vibration test. There shall be no evidence of pressure loss. At the conclusion of the vibration test, the hose assembly shall meet the leakage requirement of Paragraph 4.3. Submerge the hose assembly in isopropyl alcohol for a minimum of two (2) minutes, and then oven dry at $275 \pm 25^{\circ}$ F for a minimum of one (1) hour prior to submittal of leakage test.

4.6 Seismic

Install the hose assembly into a configuration as shown in Figure 4, into a test fixture on the vibration table with one end offset to an equivalent position of -2.88 inches in the X axis, +2.88 inches in the Y axis, and -2.88 inches in the Z axis. Pressurize the interior of the hose assembly with water at 2500 psig, and close off the pressure source.

Subject the hose assembly to the Test Response Spectrum (TRS) that as a minimum exceeds the 2 percent critical damping curve of Figure 1, except that the acceleration response at 1 HZ shall be approximately 1.5 G's and following a straight line at 16.5 G's at 2.5 HZ. Develop the TRS by means of complex random motion Vertical-Horizontal (biaxial) then Vertical -90° Horizontal, complying with the requirements of IEEE Standard 344-1975. The two TRS levels shall be of 45 seconds duration each. The test shall be performed with the hose assembly with media at zero pressure, with water at zero pressure, and with water at 2500 psig.

At the conclusion of the seismic vibration test, the hose assembly shall meet the leakage test of Paragraph 4.3.

4.7 Hydrostatic Pressure

Hydrostatic proof pressure test to be conducted per Paragraph 4. 2, except that the pressure shall be 3750 psig. After meeting the above requirements, increase pressure to the burst pressure requirement of 8750 psig. Hold for one (1) minute. Increase pressure to failure.



OTP 73989



J

Ľ

J

I.

]

1.

REPORT NO. 5410-7197 PHOTOGRAPH 2 OPERATING VIBRATION TEST SETUP (X AXIS)





]

1

finantia (

Distant

REPORT NO. 5410-7197 PHOTOGRAPH 3 OPERATING VIBRATION TEST SETUP (Y AXIS)



\$

1	2	ENGINEER	REFERENCE NUMBER	12020
METAL D	CORPORATION	R. MISTOM	HUSE TT.	PAGE OF
20977 KNAPP STR	LET LIFORNIA 91311	2-15-13	ELCHTEL	4
		1-		
			1	
3.3	OCCASIONAL	LORIS	(REP NG-365)	(2, Eg(4))
	PD.	·/Mat	-Molaria	
	Sol = 41 + .	75.2 (e,	5,
	,			
		$M_R = Z_q$	SEISMIC LO	OND
		Fun 12), 2/12/017	
	= 3,36 Kai + .75((2.1) (12.42	$\left \frac{1+C(1-r_{1})}{2}\right \leq 1$	1.2 (15.9 1/2
	•			•
	= 3.36 Kas +	4.85 Ksi	4	19.08 Ksi
		821	K, K	19 D8 Kg
		0.27 P		
		A	DEQUATE	
			2901112	
			8	•
3.4	THERMONL EXP	ANSION (REF NC-3652	2.3 , Eq(10))
	, , , , , , , , , , , , , , , , , , , ,	10	_	
	$S_{r} = \frac{z}{z}$	The = S	, A	
	<i>1-2</i> Z	-	•	
		M	= MAX LOAD	TO DEFLEC
	10	(100)		
	=	121 5 2	27.1 Kr	
	.01			
	= 18	.7 Kr 5 2	7.1 Kas	
			DEQUATE	-7
				_
			-	

· Pr	ENGINEER	REFERENCE NUMB	ER	
METAL Dation CORPORATION	DATE	CUSTOMER	PAGE	OF
20977 KNAPP STREET Chatsworth, California 91311	2.15-78	BECHTE	5	
3.5 TOTAL LOAD C.	FIECTS 1	REF 11536	52.3 Er 1	()
	(10)	()		/
ST = PD0 +.	75i(1)+	$i\left(\frac{N_{c}}{2}\right) \leq$	$(5_{h}+5_{n})$	
- 4kn	. 2			
	12.42	7,10,510	BJelison	
= 3.36 Kai +.7.	5(2.1) .0121	+(2.1)	21 = (15.9/24	*21
	-			
= 9,36Km+1.6	2 14 + 18.74	14=23.72%	= 43 Kai	
	**		•	
	T	NDENIA	7=1	
3,6 SHEAR STRESS	(THIN RI	NG)		
21				
A A				
2 (18 18))			
.7554 (.503	3/42) =0	3 Ksr		
	·	ADED	1075	
	-	1.2000		