


50-390
50-391

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

82 MAR 9
March 8 1982



U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - SEISMIC QUALIFICATION OF CONTROL
EQUIPMENT - NCR WBN EEB 8005 - FOURTH INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
M. Thomas on September 22, 1980. Interim reports were submitted on
October 22, 1980 and April 9 and July 21, 1981.

Samples of the potentially deficient control stations will be tested
for seismic qualification by Wyle Laboratories. Results of the tests
are now expected to be available by March 1983. Control stations
which fail the seismic test requirements will be replaced with
qualified units. No other TVA nuclear plants are affected by this
deficiency. TVA expects to submit our next report by June 14, 1982.

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Regulation and Safety

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8203170303 820308
PDR ADOCK 05000390
S PDR

OFFICIAL COPY

IE 22
1/0