

USNR REGION II
ATLANTA, GEORGIA
83 NOV 15 9:48

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II/5

November 8, 1983

WBRD-50-390/83-02

WBRD-50-391/83-02

U.S. Nuclear Regulatory Commission
Region II

Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - AUXILIARY INSTRUMENT ROOM FIRE DOOR
FAILURE - WBRD-50-390/83-02, WBRD-50-391/83-02 - SUPPLEMENTAL INFORMATION

The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on December 29, 1982 in accordance with 10 CFR 50.55(e) as NCR
WBN MEB 8207. Interim reports were submitted on January 27 and May 18, 1983.
Our final and revised final reports were submitted on August 19 and October 19,
1983, respectively.

As discussed with NRC-OIE Inspector Paul Fredrickson on October 26, 1983, the
date of October 31, 1983 for completion of corrective actions indicated in our
revised final report (dated October 19, 1983) on this matter would not be met.
Interferences between the wall restraints being installed and the existing
supports and ducts are delaying the completion of the Auxiliary Instrument and
the Control Building Computer Rooms' bracing effort. The corrective action on
this matter will be completed by November 30, 1983.

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills
L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

9311210448 831108
PDR ADOCK 05000390
S PDR

1983-TVA 50TH ANNIVERSARY

An Equal Opportunity Employer

OFFICIAL COPY

IE 27

1/0