

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

16 AUG 06
January 24, 1984

WBRD-50-390/83-70
WBRD-50-391/83-65

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - CONTROL ROOM PRESSURIZATION BOUNDARY
LOSS THROUGH FLOOR AND EQUIPMENT DRAINS -WBRD-50-390/83-70, WBRD-50-391/83-65 -
SECOND INTERIM REPORT


The subject deficiency was initially reported to NRC-OIE Inspector
P. E. Fredrickson on November 21, 1983 in accordance with 10 CFR 50.55(e) as NCR
WBN WBP 8335. Our first interim report was submitted on December 21, 1983.
We expect to submit our next report on or about February 17, 1984.

TVA is continuing the design evaluation of this problem. The proposed piping
support changes have been found to be unsuitable.

If you have any questions, please get in touch with R. H. Shell at
FTS 850-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8401300136 840124
PDR ADOCK 05000390
S PDR

OFFICIAL COPY

1621

1/0