

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

June 1, 1984

84 JUN 5 P12: 23

WBRD-50-390/83-64

WBRD-50-391/83-59

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - AIR FLOW RATES FOR SAFETY-RELATED ROOM EXHAUST FANS BELOW ACCEPTANCE CRITERIA WBRD-50-390/83-64, WBRD-50-391/83-59 - SUPPLEMENTAL INFORMATION

The subject deficiency was initially reported to NRC-OIE Inspector Ross Butcher on November 7, 1983 in accordance with 10 CFR 50.55(e) as NCRs WBN NEB 8329 and NEB 8330. Our first interim and final reports were submitted on December 8, 1983 and January 19, 1984 respectively.

Due to the additional failure of several dampers, the completion of the special tests has been delayed. These dampers must be replaced before balancing can be complete and the tests performed. Also, the 2550 cfm flow rate to be added to flow diagram 47W866-9 has been changed to 2850 cfm. The corrective action on this matter will be completed by June 21, 1984.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

D S Kammer

for L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8406110326 840601
PDR ADOCK 03000390
S PDR

OFFICIAL COPY

LE 27

1/0