

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

March 29, 1983

WBRD-50-390/82-71
WBRD-50-391/82-66

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - REVIEW AND UPDATING OF PIPING
DRAWINGS - WBRD-50-390/82-71, WBRD-50-391/82-66 - THIRD INTERIM REPORT


The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on June 21, 1982 in accordance with 10 CFR 50.55(e) as NCR
WBN QAB 8204. Interim reports were submitted on July 10, and November 1,
1982. We expect to submit our next report on or about September 30, 1983.

TVA has developed a method of correcting this deficiency by showing
analysis problem boundaries on issued design drawings. This method will
ensure that all piping has been analyzed. Other procedures presently in
existence will control revisions. Additional information will be provided
in our next report.

If you have any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

OFFICIAL COPY

IE 27

8304050474 830329
PDR ADOCK 05000390
S PDR