

DMB

TENNESSEE VALLEY AUTHORITY

KNOXVILLE, TENNESSEE 37902

5W 157B Lookout Place

07 JAN 7 09:36

JAN 02 1987

WBRD-50-390/81-71
WBRD-50-391/81-67

U.S. Nuclear Regulatory Commission
Region II
Attention: Dr. J. Nelson Grace, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Dear Dr. Grace:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - QUALIFICATION OF EPOXY GROUT
FOR SAFETY-RELATED APPLICATIONS - WBRD-50-390/81-71, WBRD-50-391/81-67 -
SUPPLEMENTAL INFORMATION FOR UNIT 1


The subject deficiency was initially reported to NRC-OIE Inspector
R. V. Crlenjak on August 27, 1981 in accordance with 10 CFR 50.55(e) as NCR
3567R. On December 2, 1986 Gordon Hunegs was notified of SCR WBN CEB 8570,
which documented incomplete actions for correction of the previous NCR. Our
final report was submitted on September 13, 1983 for unit 1 and on
February 13, 1986 for unit 2.

TVA has identified approximately 15 unit 1 engineered supports and one typical
hanger which still specify the use of epoxy grout. TVA is evaluating the
previous corrective action and its implementation to determine the necessary
scope of any further actions. We will submit a revised final report to NRC on
or about February 17, 1987.

If there are any questions, please get in touch with R. D. Schulz at
(615) 365-8527.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



R. Gridley, Director
Nuclear Safety and Licensing

cc: Mr. James Taylor, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. G. G. Zech
Director, TVA Projects
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8701120147 870102
PDR ADOCK 05000390
S PDR

10
EE27