

Jeff Ciocco

From: Jeff Ciocco
Sent: Wednesday, August 27, 2008 12:39 PM
To: us-apwr-rai@mhi.co.jp
Cc: Mark Lintz; Michael Junge; Michael Takacs; Larry Burkhart
Subject: US-APWR Design Certification Application RAI 60-1101
Attachments: US-APWR DC RAI 60 COLP 1101.pdf

MHI,

Attached please find the subject request for additional information (RAI). This RAI was sent to you in draft form. The schedule we established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. Please submit your RAI response to the NRC Document Control Desk.

Thanks,

Jeff Ciocco
Office: T-7F14
New Reactor Licensing
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, MD 20852-2739
301.415.6391
jeff.ciocco@nrc.gov

REQUEST FOR ADDITIONAL INFORMATION NO. 60-1101 REVISION 0

8/27/2008

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

SRP Section: 13.02.01 - Reactor Operator Requalification Program; Reactor Operator Training

Application Section: 13.2

COLP Branch

QUESTIONS

13.02.01-1

NUREG-0800, Chapter 13, Section 13.2.1, specifies the requirements for the COL applicant's reactor operator requalification program and for reactor operator training. Chapter 13, Section 13.2, of the US-APWR DC FSAR, states that development of the training programs for licensed and non-licensed plant personnel is the responsibility of the COL applicant. While information for these training programs can be plant-specific, and remains to be determined by the COL applicant, the basic structure and content for the training programs to comply with NUREG requirements should be stated in the US-APWR DC FSAR.

Additional detail needs to be added to the US-APWR DC FSAR to ensure that the COL applicant's training programs meet the requirements of NUREG-0800, Chapter 13, Section 13.2.1.