



ENERGY SERVICES GROUP

March 3, 1989

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Subject: 10CFR21 Notification

On February 23, 1989, Basler Electric informed the Commission of a condition reportable under the requirements of 10CFR21. This notification was made with specific reference to their part BEI-32 power relays.

The purpose of this letter is to inform the Commission that the thirty-six (36) relays supplied to us were installed in diesel engine generator equipment provided to TVA for the Hartsville - Phipps Bend project. To our knowledge, of the twelve (12) diesel engine units originally supplied, ten (10) have been sold for non-nuclear service.

A copy of this letter will be forwarded to TVA for their information and action.

Sincerely,

Bruce G. Guntrum
Manager, Quality Assurance

BCG/dfa

cc.: TVA
10CFR21 #207

ENTERPRISE ENGINE SERVICES

85th Avenue & Enterprise Way
PO Box 2161 Oakland, CA 94621-0061
(415) 577-7400 Telex (47) 33 5304

*IE19
110*

AJAX* • COOPER BESSEMER* • ENTERPRISE* • ENTRONIC* • NORDBERG* • PENN* • SUPERIOR* PRODUCTS

8903100191 890303
PDR ADOCK 05000518
S PDC