



Tennessee Valley Authority, 1775 Market Street, Chattanooga, Tennessee 37402

Mark O. Medford
Vice President, Nuclear Operations, Licensing and Fuels

March 26, 1993

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Gentlemen:

In the Matter of)	Docket Nos.	50-259	50-390
Tennessee Valley Authority)		50-260	50-391
)		50-296	50-438
)		50-327	50-439
)		50-328	

TVA NUCLEAR QUALITY ASSURANCE PLAN (TVA-NQA-PLN89-A, REVISION 2) - CHANGE

- References:
1. TVA letter to NRC dated November 13, 1992, "TVA Nuclear Quality Assurance Plan (TVA-NQA-PLN89-A, Revision 2) - Change"
 2. NRC letter to TVA dated January 7, 1993, "TVA Nuclear Quality Assurance Plan (TVA-NQA-PLN89-A, Revision 2) - Change"

On March 3, 1993, TVA and NRC met at Watts Bar Nuclear Plant (WBN) to discuss the proposed TVA Quality Assurance (QA) program revision submitted in Reference 1. Discussion of this change focused on TVA's implementation of Section 3.2.1 of ANSI N45.2.9-1974 (Generation of Quality Assurance Records) and the WBN corrective action plan (CAP) on vendor records. Both TVA and NRC agreed that Section 3.2.1 requires TVA to specify in our procurement documents which QA records are to be generated by, supplied to, or held for the owner by the vendor. It was further agreed that ANSI N45.2.9 does not require TVA to have every record type listed in Appendix A to the standard for a component.

9304060259 930326
PDR ADOCK 03000259
PDR

9004
1/0

U.S. Nuclear Regulatory Commission

Page 2


March 26, 1993

Discussion of the WBN vendor records CAP resulted in agreement that the CAP commits TVA to review on a sampling basis all record types listed in Appendix A to ANSI N45.2.9, but does not require that TVA or its suppliers have all records on the list for a given component.

Based on the understandings described above, we withdraw the request submitted in Reference 1.

If you have any questions regarding this submittal, please telephone Ralph H. Shel: at 615/751-2474.

Sincerely,

A handwritten signature in cursive script, appearing to read "Mark O. Medford".

Mark O. Medford

cc: See page 3

U.S. Nuclear Regulatory Commission
Page 3
March 26, 1993

cc: U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

Mr. Peter S. Tam, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Watts Bar Resident Inspector
Watts Bar Nuclear Plant
P.O. Box 700
Spring City, Tennessee 37381

Mr. Thierry M. Ross, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

NRC Resident Inspector
Browns Ferry Nuclear Plant
Route 12, P.O. Box 637
Athens, Alabama 35611

Mr. M. C. Thadani, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852