

ATTACHMENT (2)

MARKED UP TECHNICAL SPECIFICATION PAGES

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition C not met.	D.1 Be in MODE 3.	6 hours
	<u>AND</u> D.2 Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.2.1 Verify closure time of each MSIV is 5.2 seconds . <i>within limits</i>	In accordance with the Inservice Testing Program